

NORTH HERTS COUNCIL

MEMORANDUM

To: PLANNING CONTROL AND CONSERVATION Tom Rea	From: ENVIRONMENTAL HEALTH Alan Stone Ext 4108
	Date: 8 th January 2025
Our Ref: 6121/25	Your : 24/02596/FP Ref:
Subject: Full Planning Application: Conversion of loft to create flat and conversion of first floor of garage to create second flat and associated development Gun House, Gun Lane, Knebworth, Hertfordshire	

Comments:

Thank you for consulting Environmental Protection on this application.

This is an amended proposals to the previously submitted 24/00194/FP. I can comment on noise/nuisance, land contamination and air quality as follows.

Noise/Nuisance:

The proposed windows have been removed from the front façade on the current plans and have been replaced by a rear dormer window and a side roof light. Given that the line of sight to the railway line has been removed, I no longer require a noise assessment and have no objections to the proposals in terms of noise. There are, however, some inconsistencies on the elevational drawings, but I am assuming that the window placements do not form part of these inconsistencies.

Land Contamination:

The proposals are within existing buildings. I, therefore, have no comments in relation to land contamination.

Local Air Quality:

North Herts Council have specific air quality planning guidance that can be found at <http://www.north-herts.gov.uk/home/environmental-health/pollution/air-quality/air-quality-and-planning>

Application of the guidance to a development of this scale and location defines the site as being a MINOR scale development and so the following condition is recommended to ensure that appropriate local air quality mitigation is provided.

EV Recharging Infrastructure Condition

Prior to occupation, the new dwelling shall incorporate an Electric Vehicle (EV) ready domestic charging point.

Reason: To contribute to the objective of providing a sustainable transport network and to provide the necessary infrastructure to help off-set the adverse impact of the operational phase of the development on local air quality.

Informative

1) EV Charging Point Specification:

A charging point shall be installed by an appropriately certified electrician/electrical contractor in accordance with the following specification. The necessary certification of electrical installation should be submitted as evidence of appropriate installation to meet the requirements of Part P of the most current Building Regulations.

Cable and circuitry ratings should be of adequate size to ensure a minimum continuous current demand for the vehicle of 16A and a maximum demand of 32A (which is recommended for Eco developments)

- A separate dedicated circuit protected by an RBCO should be provided from the main distribution board, to a suitably enclosed termination point within a garage or an accessible enclosed termination point for future connection to an external charge point.
- The electrical circuit shall comply with the Electrical requirements of BS7671: 2008 as well as conform to the IET code of practice on Electric Vehicle Charging Equipment installation 2012 ISBN 978-1-84919-515-7 (PDF). This includes requirements such as ensuring the Charging Equipment integral protective device shall be at least Type A RCD (required to comply with BS EN 61851 Mode 3 charging).
- If installed in a garage all conductive surfaces should be protected by supplementary protective equipotential bonding. For vehicle connecting points installed such that the vehicle can only be charged within the building, e.g. in a garage with a (non-extended) tethered lead, the PME earth may be used. For external installations the risk assessment outlined in the IET code of practice must be adopted, and, may require additional earth stake or mat for the EV charging circuit. This should be installed as part of the EV ready installation to avoid significant on cost later.
- A list of authorised installers (for the Government's Electric Vehicle Homecharge Scheme) can be found at <https://www.gov.uk/government/organisations/office-for-low-emission-vehicles>
- UK Government issued legislation in 2021 to require domestic EV charge points to be smart, thus we recommend that all charge points will be capable of smart charging, as detailed in UK Gov regulations.

2) The above condition is considered relevant and reasonable for the following reasons:

- Paragraphs 170 (e), 181 of the NPPF, which refer to the effects (including cumulative effects) of pollution (including air pollution) on health, the natural environment (including air quality).

- Paragraphs 102 (d), 105 (e) and 110 (e) of the NPPF, which refer to the need to promote sustainable transport including the provision for charging plug-in and other ultra low emission vehicles.
- HCC Local Transport Plan (LTP4) 2018-2031 which includes an objective to 'preserve the character and quality of the Hertfordshire environment' and 'make journeys and their impact safer and healthier', as well as its Emissions Reduction Policy 19.
- It is consistent with the approach specified in the NHDC Air Quality Planning Guidance Document, which is referenced within the current consultation version of the Local Plan.

If you have any queries then please do not hesitate to contact me

Regards

Alan Stone