
Fwd: Redevelopment of Ridge Farm, Rabley Heath Road, Codicote - FIRE HYDRANT SUPPLY1 message

Ariadna Aston [REDACTED]

Begin forwarded message:

From: Water <[REDACTED]>
Subject: RE: Redevelopment of Ridge Farm, Rabley Heath Road, Codicote - FIRE HYDRANT SUPPLY
Date: 11 December 2025 at 12:19:51 GMT
To: [REDACTED] >

Hi Nigel

Sorry for the delay in responding I have been on leave

I have attached the screen shot below from our mapping software showing the nearest Fire Hydrant (009836)
As you can see, we would require a1x Fire Hydrant
The most efficient option would be on the main in the road as the properties
Would come in under the 90m

Happy to discuss

Many thanks

Paul

Paul Redhead

Water Officer |Fire & Rescue|Community Protection Directorate
Hertfordshire County Council
Address: Technical Services, 9 Merchant Drive Mead Lane Hertford
SG13 7BH. W3W /// castle.cowboy.herbs
[REDACTED]

[Our vision](#) is to create a cleaner, greener and healthier
Hertfordshire, guided by our RISE values

From: Elizabeth Sanderson <[REDACTED]> **On Behalf Of** CPD Customer Services
Sent: 01 December 2025 13:08
To: Water <[REDACTED]>
Subject: FW: Redevelopment of Ridge Farm, Rabley Heath Road, Codicote - FIRE HYDRANT SUPPLY

Please see the email below received via the CPD Customer Services inbox.

Could you please action/respond directly to the requester – no need to copy me/CPD inbox in to your response.

Many thanks

On behalf of the Community Protection Directorate (CPD) Customer Services inbox.

From: Nigel Grace <[REDACTED]>
Sent: 01 December 2025 12:14
To: CPD Customer Services <[REDACTED]>
Subject: Redevelopment of Ridge Farm, Rabley Heath Road, Codicote - FIRE HYDRANT SUPPLY

You don't often get email from [REDACTED]

Hello,

I am seeking you advice as to who can help me within Hertfordshire Fire & Rescue Service with regards to fire hydrant supplies.

We are working on the redevelopment of Ridge Farm in Codicote and are seeking your direction as to whether a fire hydrant supply will be required for the site.

Attached are two drawings;

1. Existing site layout
2. Proposed site plan showing the four new houses


The distance from the Rabley Heath Road to the end of the two access routes are approximately 67m and 86m.

Please can you let me know who within HRFS I should contact to get further advice and direction on whether you will require a fire hydrant supply to the development.

Thank you.

Nigel.

Nigel Grace MRICS, MIOB
Director
NKG Investments Limited



Disclaimer

This email and any attachments are intended solely for the named recipient(s) and may contain confidential or legally privileged information. If you are not the intended recipient, please delete this message and notify the sender immediately. The views expressed in this email are those of the author and do not necessarily reflect those of Hertfordshire County Council (HCC), unless explicitly stated. HCC monitors and may retain email communications in accordance with its policies and legal obligations. Monitoring is conducted to ensure compliance with council procedures, prevent or detect crime, and support essential system maintenance.

Please consider the environment before printing this email.

For more information on how we handle personal data, please refer to our [privacy policy](#).

