

DELEGATED FILE NOTE

CASE OFFICER: ...Andrew Hunter.....

APPLICATION REFERENCE	BRIEF DESCRIPTION OF DEVELOPMENT	APPLICATION SITE
24/02911/LDCP	Insertion of rear box dormer, second floor side window and 2no front roof lights to facilitate conversion of loft into habitable accommodation	27 Grange Rise Codicote Hitchin Hertfordshire SG4 8YR

Submitted Plan Nos

6075-P01-B 6075-E01 6075-P01-A 6075-OS1 6075-OS2

1.0 Policies

2.0 **Relevant Site History**

2.1 None.

3.0 **Representations**

3.1 No consultation required.

4.0 **Planning Considerations**

4.1 **Site and Surroundings**

4.1.1 The site is a semi-detached two storey dwelling with a pitched roof.

4.2 **Proposal**

4.2.1 A Certificate of Lawfulness (proposed) is sought for a rear dormer window with a flat roof, two new front rooflights, and the insertion of a second floor side window.

4.3 **Key Issues**

4.3.1 The key issues for consideration are whether the proposed development would require a specific planning permission or be considered 'permitted development' in line with the Town and Country Planning (General Permitted Development) Order 2015, Schedule 2, Part 1, Class A, Class B, and Class C. Permitted development rights have not been removed by condition.

4.3.2 **A. The enlargement, improvement or other alteration of a dwellinghouse.**

A.1 Development is not permitted by Class A if—

(a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule (changes of use);

The proposed development is compliant with this criterion.

(b) as a result of the works, the total area of ground covered by buildings within the curtilage of the dwellinghouse (other than the original dwellinghouse) would exceed 50% of the total area of the curtilage (excluding the ground area of the original dwellinghouse);

The proposed development is compliant with this criterion.

(c) the height of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the highest part of the roof of the existing dwellinghouse;

The proposed development is compliant with this criterion.

(d) the height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse;

The proposed development is compliant with this criterion.

**(e) the enlarged part of the dwellinghouse would extend beyond a wall which—
(i) forms the principal elevation of the original dwellinghouse; or
(ii) fronts a highway and forms a side elevation of the original dwellinghouse;**

The proposed development is compliant with this criterion.

**(f) subject to paragraph (g), the enlarged part of the dwellinghouse would have a single storey and—
(i) extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse, or
(ii) exceed 4 metres in height;**

The proposed development is compliant with this criterion.

**(g) for a dwellinghouse not on article 2(3) land nor on a site of special scientific interest, the enlarged part of the dwellinghouse would have a single storey and—
(i) extend beyond the rear wall of the original dwellinghouse by more than 8 metres in the case of a detached dwellinghouse, or 6 metres in the case of any other dwellinghouse, or
(ii) exceed 4 metres in height;**

The proposed development is compliant with this criterion.

**(h) the enlarged part of the dwellinghouse would have more than a single storey and—
(i) extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or
(ii) be within 7 metres of any boundary of the curtilage of the dwellinghouse opposite the rear wall of the dwellinghouse;**

The proposed development is compliant with this criterion.

(i) the enlarged part of the dwellinghouse would be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would exceed 3 metres;

The proposed development is compliant with this criterion.

**(j) the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse, and would—
(i) exceed 4 metres in height,
(ii) have more than a single storey, or
(iii) have a width greater than half the width of the original dwellinghouse; or**

The proposed development is compliant with this criterion.

**(k) it would consist of or include—
(i) the construction or provision of a verandah, balcony or raised platform,**

- (ii) the installation, alteration or replacement of a microwave antenna,
- (iii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or
- (iv) an alteration to any part of the roof of the dwellinghouse.

The proposed development is compliant with this criterion.

A.2 In the case of a dwellinghouse on article 2(3) land, development is not permitted by Class A if—

(a) it would consist of or include the cladding of any part of the exterior of the dwellinghouse with stone, artificial stone, pebble dash, render, timber, plastic or tiles;

(b) the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse; or

(c) the enlarged part of the dwellinghouse would have more than a single storey and extend beyond the rear wall of the original dwellinghouse.

N/A – The application site is not on Article 2(3) land.

Conditions

A.3 Development is permitted by Class A subject to the following conditions—

(a) the materials used in any exterior work (other than materials used in the construction of a conservatory) must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

The proposed development is compliant with this condition.

(b) any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse must be—

(i) obscure-glazed, and

(ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed; and

This is shown on the proposed drawing. The proposed development is compliant with this condition.

(c) where the enlarged part of the dwellinghouse has more than a single storey, the roof pitch of the enlarged part must, so far as practicable, be the same as the roof pitch of the original dwellinghouse.

The proposed development is compliant with this condition.

4.3.3 B. The enlargement of a dwellinghouse consisting of an addition or alteration to its roof.

Development is not permitted

B.1 Development is not permitted by Class B if—

(a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule (changes of use);

The proposal complies with this criterion.

(b)any part of the dwellinghouse would, as a result of the works, exceed the height of the highest part of the existing roof;

The proposal complies with this criterion.

(c)any part of the dwellinghouse would, as a result of the works, extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway;

The proposal complies with this criterion.

(d)the cubic content of the resulting roof space would exceed the cubic content of the original roof space by more than—

**(i)40 cubic metres in the case of a terrace house, or
(ii)50 cubic metres in any other case;**

The application dwelling is a semi-detached dwelling and therefore additions to the roof can exceed the original roof space of the dwelling by no more than 50 cubic metres. The existing roof is considered to be the original roof. The volume of the proposed roof addition would be approx. 24.2 m³.

The proposal complies with this criterion.

(e)it would consist of or include—

**(i)the construction or provision of a verandah, balcony or raised platform, or
(ii)the installation, alteration or replacement of a chimney, flue or soil and vent pipe; or**

The proposal complies with the criterion.

(f)the dwellinghouse is on article 2(3) land.

The proposal complies with this criterion.

Conditions

B.2 Development is permitted by Class B subject to the following conditions—

(a)the materials used in any exterior work must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

This is stated on the application form. The proposal complies with this criterion.

(b)the enlargement must be constructed so that—

(i)other than in the case of a hip-to-gable enlargement or an enlargement which joins the original roof to the roof of a rear or side extension—

(aa)the eaves of the original roof are maintained or reinstated; and

(bb)the edge of the enlargement closest to the eaves of the original roof is, so far as practicable, not less than 0.2 metres from the eaves, measured along the roof slope from the outside edge of the eaves; and

The proposal complies with this criterion.

(ii)other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement extends beyond the outside face of any external wall of the original dwellinghouse; and

(c)any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse must be—

(i)obscure-glazed, and

(ii)non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.

The proposal complies with this criterion.

4.3.4 Proposed Rooflights to Front Roof - C. Any other alteration to the roof of a dwellinghouse.

C.1 Development is not permitted by Class C if—

(a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule (changes of use);

The proposed development is compliant with this criterion.

(b) the alteration would protrude more than 0.15 metres beyond the plane of the slope of the original roof when measured from the perpendicular with the external surface of the original roof;

The proposed development is compliant with this criterion.

(c) it would result in the highest part of the alteration being higher than the highest part of the original roof; or

The proposed development is compliant with this criterion.

(d) it would consist of or include—

(i) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or

(ii) the installation, alteration or replacement of solar photovoltaics or solar thermal equipment.

The proposed development is compliant with this criterion.

Conditions

C.2 Development is permitted by Class C subject to the condition that any window located on a roof slope forming a side elevation of the dwellinghouse must be—

(a) obscure-glazed; and

(b) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.

N/A

4.4 Conclusion

- 4.4.1 A Certificate of Lawfulness (proposed) can be issued on the basis that the proposed 'Insertion of rear box dormer, second floor side window and 2no front roof lights to facilitate conversion of loft into habitable accommodation' **would** constitute permitted development by virtue of Class A, Class B, and Class C, Part 1 of Schedule 2 of the Town and Country Planning (General Permitted Development) (England) Order 2015 as amended.

Signed  Melissa Tyler	Development Management North Hertfordshire District Council Council Offices Gernon Road Letchworth Herts SG6 3JF
Determining Officer Date: 30 January 2025	