



www.north-herts.gov.uk

NORTH HERTFORDSHIRE DISTRICT COUNCIL

Town and Country Planning Act 1990

DECISION NOTICE

Correspondence Address:

Pentangle Design Group
Suite 1
21 Bancroft
Hitchin
SG5 1JW
United Kingdom

Applicant:

Mr Paul Shadbolt

PARTICULARS OF DEVELOPMENT

Application: 26/00116/FP

Proposal: Erection of four detached dwellings and detached garage to serve plot 4 including hard and soft landscaping, parking and creation of vehicular access. (Amended plans received 01/07/26 and 14/09/26).

Location: 19 Walnut Tree Road, Pirton, Hitchin, Hertfordshire, SG5 3PX

Plan Nos: 3942 06G
3942 12B
3942 14A - Plot 1
3942 16A - Plot 1
3942 15A - Plot 1
3942 01D
3942 17A - Plot 2
3942 18A - Plot 2
3942 19A - Plot 2
3942 20 - Plot 3
3942 21 - Plot 3
3942 22 - Plot 3
3954 24D - Plot 4
TS25-677-1
318-2025-012-P2
318-2025-011-P3 -
3954 23B - Plot 4
3954 25A - Plot 4

PARTICULARS OF DECISION

In pursuance of its powers under the above Act and the associated Orders and Regulations, the Council hereby **GRANT PERMISSION** for the development proposed by you in your application received with sufficient particulars on 30 January 2026, subject to the following condition(s):

Biodiversity Net Gain

1. The effect of paragraph 13 of Schedule 7A to the Town and Country Planning Act 1990 is that planning permission granted for the development of land in England is deemed to have been granted subject to the condition "(the biodiversity gain condition)" that development may not begin unless:
(a) a Biodiversity Gain Plan has been submitted to the planning authority, and
(b) the planning authority has approved the plan.
The planning authority, for the purposes of determining whether to approve a Biodiversity Gain Plan if one is required in respect of this permission would be North Hertfordshire District Council.
There are statutory exemptions and transitional arrangements which mean that the biodiversity gain condition does not always apply (<https://www.gov.uk/guidance/biodiversity-net-gain-exempt-developments>).
Based on the information available this permission is considered to be one which will require the approval of a biodiversity gain plan before development is begun because none of the statutory exemptions or transitional arrangements are considered to apply.

Planning Conditions

1. The development hereby permitted shall be begun before the expiration of 3 years from the date of this permission.

Reason: To comply with the provisions of Section 91 of the Town and Country Planning Act 1990 as amended by Section 51 of the Planning and Compulsory Purchase Act 2004.
2. The development hereby permitted shall be carried out wholly in accordance with the details specified in the application and supporting approved documents and plans listed above.

Reason: To ensure the development is carried out in accordance with details which form the basis of this grant of permission.
3. Details and/or samples of materials to be used on all external elevations and the roof of the development hereby permitted shall be submitted to and approved in writing by the Local Planning Authority before the development is commenced and the approved details shall be implemented on site.

Reason: To ensure that the development will have an acceptable appearance which does not detract from the appearance and character of the surrounding area and to comply with Policy D1 of the North Hertfordshire Local Plan 2011 to 2031.

4. Prior to the commencement of the development hereby permitted full details of a comprehensive hard and soft landscaping scheme (including planting details) and all boundary treatments shall be submitted to and approved in writing by the Local Planning Authority.

All approved hard standing and boundary treatments shall be completed prior to the first occupation of the development.

The approved soft landscaping / planting details shall be carried out before the end of the first planting season following either the occupation of the (first) dwelling or the completion of the development, whichever is the sooner; and any trees or plants which, within a period of 5 years from the completion of the development, die, are removed or become seriously damaged or diseased, shall be replaced during the next planting season with others of similar size and species, unless the Local Planning Authority agrees in writing to vary or dispense with this requirement.

Reason: To ensure the development is comprehensively landscaped in the interests of visual amenity. Local Plan Policies D1 and N2.

5. No development shall take place before details of the proposed finished floor levels; ridge and eaves heights of the building hereby approved have been submitted to and approved in writing by the Local Planning Authority. The submitted levels details shall be measured against a fixed datum and shall show the existing and finished ground levels, eaves and ridge heights of surrounding properties. The development shall be carried out as approved.

Reason: To ensure that the finished appearance of the development will enhance the character and visual amenities of the area and to comply with Policy D1 of the Local Plan

6. None of the trees to be retained on the application site shall be felled, lopped, topped, uprooted, removed or otherwise destroyed or killed without the prior written agreement of the Local Planning Authority.

Reason: To safeguard and enhance the appearance of the completed development and the visual amenity of the locality, and to comply with Policy NE2 of the North Hertfordshire Local Plan 2011 to 2031.

7. Any tree felled, lopped, topped, uprooted, removed or otherwise destroyed or killed contrary to the provisions of the tree retention condition above shall be replaced during the same or next planting season with another tree of a size and species as agreed in writing with the Local Planning Authority, unless the Authority agrees in writing to dispense with this requirement.

Reason: To safeguard and enhance the appearance of the completed development and the visual amenity of the locality, and to comply with Policy NE2 of the North Hertfordshire Local Plan 2011 to 2031.

8. Before the commencement of any other works on the site, trees to be retained shall be protected by the erection of temporary chestnut paling or chain link fencing of a minimum height of 1.2 metres on a scaffolding framework, located at the appropriate minimum distance from the tree trunk in accordance with Section 4.6 of BS5837:2012 'Trees in relation to design, demolition and construction - Recommendations, unless in any particular case the Local Planning Authority agrees to dispense with this requirement. The fencing shall be maintained intact for the duration of all engineering and building works. No building materials shall be stacked or mixed within 10 metres of the tree. No fires shall be lit where flames could extend to within 5 metres of the foliage, and no notices shall be attached to trees.

Reason: To prevent damage to or destruction of trees to be retained on the site in the interests of the appearance of the completed development and the visual amenity of the locality, and to comply with Policy NE2 of the North Hertfordshire Local Plan 2011 to 2031.

9. No development approved by this permission shall take place until a Phase 2 investigation report, as recommended by the previously submitted Environmental Protection Strategies Ltd report dated 27th October 2025 (Ref: UK25.7600), has been submitted to and approved in writing by the Local Planning Authority. Where found to be necessary by the phase 2 report a remediation strategy to deal with the risks associated with contamination of the site shall also be submitted to and approved in writing by the Local Planning Authority. The remediation strategy shall include an options appraisal giving full details of the remediation measures required and how they are to be undertaken. The strategy shall include a plan providing details of how the remediation works shall be judged to be complete and arrangements for contingency action.

Reason: To prevent unacceptable risk to Human Health and Controlled Waters and to prevent pollution of the Environment in accordance with the aims and Paragraphs 187(f), 196 and 197 of the National Planning Policy Framework (December 2024).

10. Prior to any permitted dwelling being occupied a validation report shall be submitted and approved in writing by the Local Planning Authority to demonstrate the effectiveness of any agreed Remediation Strategy. Any such validation shall include responses to any unexpected contamination discovered during works.

Reason: To prevent unacceptable risk to Human Health and Controlled Waters and to prevent pollution of the Environment in accordance with the aims and Paragraphs 187(f), 196 and 197 of the National Planning Policy Framework (December 2024).

11. In the event that contamination not identified in the ground investigations is found at any time when carrying out the approved development, it shall be reported in writing immediately to the Local Planning Authority. An investigation and risk assessment shall then be undertaken by a competent person, in accordance with

BS10175:2026. A written report of the findings should be forwarded for approval to the Local Planning Authority. Following completion of remedial measures a verification report shall be prepared that demonstrates the effectiveness of the remediation carried out. No part of the development should be occupied until all remedial and validation works are approved in writing.

Reason: To prevent unacceptable risk to Human Health and Controlled Waters and to prevent pollution of the Environment in accordance with the aims and Paragraphs 187(f), 196 and 197 of the National Planning Policy Framework (December 2024).

12. Prior to the first occupation of the development hereby permitted a visibility splay shall be provided in full accordance with the details indicated on the approved drawing number (318/2025/011 P3) The splay shall thereafter be retained at all times free from any obstruction between 600mm and 2 meters above the level of the adjacent highway carriageway.

Reason: To ensure that the level of visibility for pedestrians, cyclists and vehicles is satisfactory in the interests of highway safety in accordance with Policy 5 of Hertfordshire's Local Transport Plan (adopted 2018).

13. No development shall commence until a Construction Management Plan (or Construction Method Statement) has been submitted to and approved in writing by the Local Planning Authority, including elements of the CLOCS standards as set out in the Highway Authority's Construction Management template. Thereafter the construction of the development shall only be carried out in accordance with the approved Plan: The Construction Management Plan / Statement shall include details of:

- Access arrangements to the site;
- Traffic management requirements
- Construction and storage compounds (including areas designated for car parking, loading/unloading and turning areas);
- Siting and details of wheel washing facilities;
- Cleaning of site entrances, site tracks and the adjacent public highway;
- Timing of construction activities (including delivery times and removal of waste) and to avoid school pick up/drop off times;
- Provision of sufficient on-site parking prior to commencement of construction activities;
- Post construction restoration/reinstatement of the working areas and temporary access to the public highway;
- Where works cannot be contained wholly within the site a plan should be submitted showing the site layout on the highway including extent of hoarding, pedestrian routes and remaining road width for vehicle movements

Reason: In order to protect highway safety and the amenity of other users of the public highway and rights of way in accordance with Policies 5, 12, 17 and 22 of Hertfordshire's Local Transport Plan (adopted 2018).

14. Prior to the commencement of any demolition or construction of the development, in accordance with the technical note reference 175/2026/001/JAH dated 13 August 2026 and enclosed drainage strategy drawings prepared by GHBullard & Associates LLP, detailed designs of a surface water drainage scheme in accordance with the National Standards for SuDS 2025 and incorporating the following measures shall be submitted to and agreed with the Local Planning Authority. The approved scheme shall be constructed and will be implemented prior to the first occupation of the development. The scheme shall address the following matters:

1. Detailed infiltration testing in accordance with BRE Digest 365 (or equivalent) along the length and proposed depth of the proposed infiltration feature/s

Or, if infiltration is unviable

Surface water runoff rates will be attenuated to 1 l/s and discharged to the ordinary watercourse.

2. Provision of interception for the first 5mm of rainfall for the majority of rainfall events.

3. Provision of multiple surface water attenuation storage features, sized and designed to accommodate the volume of water generated in all rainfall events up to and including the critical storm duration for the 3.33% AEP and 1% AEP rainfall events (both including allowances for climate change).

4. Detailed designs, modelling calculations and drawings of the of the drainage storage and conveyance network in the:

a. 3.33% AEP critical rainfall event plus climate change to show no flooding outside the drainage features on any part of the site.

b. 1% AEP critical rainfall plus climate change event to show, if any, the depth, volume and storage location of any flooding outside the drainage features, ensuring that flooding does not occur in any part of a building or any utility plant susceptible to water (e.g. pumping station or electricity substation) within the development. It will also show that no runoff during this event will leave the site uncontrolled.

c. Attenuation features will half drain their runoff volume rainfall events up to the 3.3% AEP critical rainfall event within 24 hours for infiltration and 48 hours for lined systems.

d. Urban Creep of 10% shall be added to impermeable areas of residential properties.

5. Detailed designs of the proposed daylighted watercourse including gradient, side slopes, finished ground levels and planting regime.

6. Finished ground floor levels of residential properties are a minimum of 300mm above expected flood levels of all sources of flooding (including the ordinary watercourses, SuDS features and within any proposed drainage scheme) or 150mm above ground level, whichever is the more precautionary.

Reason: To prevent flooding in accordance with National Planning Policy Framework paragraphs F7, F8 and N2(1) (e) plus National SuDS Standards 1 to 7, by ensuring the satisfactory management of local sources of flooding surface water flow paths, storage and disposal of surface water from the site in a range of rainfall events and ensuring the SuDS proposed operates as designed for the lifetime of the development.

15. Prior to the commencement of any demolition or construction of the development, a construction phase surface water management plan for the site will be submitted to and approved in writing by the Local Planning Authority. This plan shall provide full details of who will be responsible for maintaining such temporary systems and demonstrate how the site will be drained to ensure there is no increase in the off-site flows, nor any pollution, debris and sediment to any receiving watercourse or sewer system. The temporary drainage scheme shall subsequently be implemented in accordance with the approved details prior to and during the construction phase and be appropriately decommissioned following the final drainage scheme being validated as operational. Survey and photographic evidence of remediation shall be supplied for any permanent SuDS used in the temporary scheme, prior to being made operational.

Reason: To ensure that the construction of the site is appropriately managed in accordance with National SuDS Standard 7, does not result in any flooding both on and off site in accordance with NPPF, and that the ordinary watercourse is adequately protected.

16. Prior to the commencement of the deculverting of the ordinary watercourse, an impact assessment (which may include hydraulic modelling incorporating upstream catchments) shall be undertaken, submitted to, and approved in writing by the Local Planning Authority. The assessment shall demonstrate that the deculverting will not result in an increase in flood risk elsewhere. The assessment should consider the proposed ground levels, the detailed design of the daylighted ordinary watercourse, and any proposed crossings.

Reason: To ensure that the development achieves a high standard of sustainability and ensure the flood risk is adequately addressed for each new dwelling and not increased in accordance with NPPF F8 and Local Plan Policies of North Hertfordshire District Council.

17. The development hereby approved shall not be occupied until details of the maintenance and management of the Sustainable Drainage Scheme (SuDS) in accordance with National SuDS Standard 7 have been submitted to and approved in writing by the Local Planning Authority. The drainage scheme shall be implemented prior to the first occupation of the development hereby approved and thereafter managed and maintained in accordance with the approved details in perpetuity. The Local Planning Authority shall be granted access to inspect the sustainable drainage scheme for the lifetime of the development. The details of the network in addition to those listed in SuDS Standard 7 to be submitted for approval shall include:

1. A timetable for its implementation.

1. Details of SuDS feature and connecting drainage structures and maintenance requirement for each aspect including a non-technical labelled drawing showing where they are located and how to access them.

2. A management and maintenance plan for the lifetime of the development which shall include the arrangements for adoption by any public body or statutory undertaker, or any other arrangements to secure the operation of the sustainable drainage scheme throughout its lifetime. This will include the name and contact details of any appointed management company.

Reason: To ensure that the development achieves a high standard of sustainability and ensure the flood risk is adequately addressed for each new dwelling and not increased in accordance with NPPF and Local Plan Policies of North Hertfordshire District Council.

18. A No demolition/development shall take place/commence until an Archaeological Written Scheme of Investigation has been submitted to and approved by the local planning authority in writing. The scheme shall include an assessment of archaeological significance and research questions; and:

1. The programme and methodology of site investigation and recording and preservation in situ of heritage assets if required
2. The programme for post investigation assessment
3. Provision to be made for analysis of the site investigation and recording
4. Provision to be made for publication and dissemination of the analysis and records of the site investigation
5. Provision to be made for archive deposition of the analysis and records of the site investigation
6. Provision to be made for public engagement and interpretation
7. Nomination of a competent person or persons/organisation to undertake the works set out within the Archaeological Written Scheme of Investigation.

B The demolition/development shall take place/commence in accordance with the programme of archaeological works set out in the Written Scheme of Investigation approved under condition (A)

C The development shall not be occupied/used until the site investigation and post investigation assessment has been completed in accordance with the programme set out in the Written Scheme of Investigation approved under condition (A) and the provision made for analysis and publication where appropriate.

Reason: In the interest of preserving archaeological assets, to comply with policy HE1 and HE4 of the North Herts Local Plan 2011-2031.

19. Notwithstanding the provisions of the Town and Country Planning (General Permitted Development) Order 2015 as amended no development as set out in Classes A, AA, C, E and F of Part 1 (and any further new class that may be

introduced by way of an update) of Schedule 2 to the Order, (or any subsequent Statutory Instrument which revokes, amends and/or replaces those provisions) shall be carried out without first obtaining a specific planning permission from the Local Planning Authority.

Reason: Given the nature of this development, the Local Planning Authority considers that development which would normally be "permitted development" should be retained within planning control in the interests of the character and amenities of the area and to comply with Policy D1 and/or Policy D3 of the North Hertfordshire Local Plan 2011 to 2031.

20. The dwellings hereby approved shall not be occupied until the improvements to the vehicular access to the Pirton Recreation Ground, as shown on plan 3942 06G is completed.

Reason: In the interest of public amenity, and to comply with the provisions of Policy D1, SP2 and SP5 of the North Herts Local Plan 2011-2031.

Proactive Statement:

Planning permission has been granted for this proposal. The Council acted proactively through positive engagement with the applicant during the determination process which led to improvements to the scheme. The Council has therefore acted proactively in line with the requirements of the Framework (paragraph 38) and in accordance with the Town and Country Planning (Development Management Procedure) (England) Order 2015.

Informative/s:

1. AN1)Storage of materials: The applicant is advised that the storage of materials associated with the construction of this development should be provided within the site on land which is not public highway, and the use of such areas must not interfere with the public highway. If this is not possible, authorisation should be sought from the Highway Authority before construction works commence. Further information is available via the County Council website at: <https://www.hertfordshire.gov.uk/services/highways-roads-and-pavements/business-and-developer-information/business-licences/business-licences.aspx> or by telephoning 0300 1234047.
AN2)Obstruction of highway: It is an offence under section 137 of the Highways Act 1980 for any person, without lawful authority or excuse, in any way to wilfully obstruct the free passage along a highway or public right of way. If this development is likely to result in the public highway or public right of way network becoming routinely blocked (fully or partly) the applicant must contact the Highway Authority to obtain their permission and requirements before construction works commence. Further information is available via the County Council website at: <https://www.hertfordshire.gov.uk/services/highways-roads-and-pavements/business-and-developer-information/business-licences/business-licences.aspx> or by telephoning 0300 1234047.

AN3) Debris and deposits on the highway: It is an offence under section 148 of the Highways Act 1980 to deposit compost, dung or other material for dressing land, or any rubbish on a made up carriageway, or any or other debris on a highway to the interruption of any highway user. Section 149 of the same Act gives the Highway Authority powers to remove such material at the expense of the party responsible. Therefore, best practical means shall be taken at all times to ensure that all vehicles leaving the site during construction of the development and use thereafter are in a condition such as not to emit dust or deposit mud, slurry or other debris on the highway. Further information is available by telephoning 0300 1234047.

AN4) Works within the highway (section 278): The applicant is advised that in order to comply with this permission it will be necessary for the developer of the site to enter into an agreement with Hertfordshire County Council as Highway Authority under Section 278 of the Highways Act 1980 to ensure the satisfactory completion of the access and associated road improvements. The construction of such works must be undertaken to the satisfaction and specification of the Highway Authority, and by a contractor who is authorised to work in the public highway. Before works commence the applicant will need to apply to the Highway Authority to obtain their permission and requirements. Further information is available via the County Council website at:

<https://www.hertfordshire.gov.uk/services/highways-roads-and-pavements/business-and-developer-information/development-management/highways-development-management.aspx> or by telephoning 0300 1234047.

AN5) Avoidance of surface water discharge onto the highway: The applicant is advised that the Highway Authority has powers under section 163 of the Highways Act 1980, to take appropriate steps where deemed necessary (serving notice to the occupier of premises adjoining a highway) to prevent water from the roof or other part of the premises falling upon persons using the highway, or to prevent so far as is reasonably practicable, surface water from the premises flowing on to, or over the footway of the highway.

2. Erection of flow control structures or any culverting (or deculverting) of an ordinary watercourse requires consent from the appropriate authority, which in this instance is Hertfordshire Lead Local Flood Authority. It is advised to discuss proposals for any works at an early stage of proposals.

Both FEH13 and FEH22 are currently accepted to support drainage modelling calculations. For the avoidance of doubt the use of FSR and FEH1999 data has been superseded and therefore, use in rainfall simulations are not accepted.

Signed:



Shaun Greaves
Development and Conservation Manager

Development Management
North Hertfordshire District Council
Council Offices
Gernon Road
Letchworth
Herts
SG6 3JF

Date: 6 October 2026

The Council's Privacy Notice is available on our website: <https://www.north-herts.gov.uk/home/council-data-and-performance/data-protection/information-management-gdpr>

NOTES

- 1 **Failure to satisfy conditions may invalidate this permission and/or result in enforcement action. Particular attention should be paid to the requirements of any condition in bold.**
- 2 Applicants will need to pay a compliance fee where they request confirmation in writing of any planning consent, agreement or approval (commonly known as discharge of conditions) required by one or more conditions or limitations attached to a grant of planning permission.
- 3 The fee is £309 per request or £89 where the permission relates to an extension or alteration to a dwellinghouse or other development in the curtilage of the dwellinghouse.

The request can be informal through the submission of a letter or plans, or formal through the completion of an application form and the submission of plans. Any number of conditions may be included on a single request. The form is available via the Council's website:
www.north-herts.gov.uk/home/planning/planning-applications/submit-planning-application
- 4 If the development hereby permitted is one that will require a new postal address/es then please contact the Council's **street naming and numbering service** on 01462 474431 or email SNN@north-herts.gov.uk who will advise you on how to apply for the new address/es.

Any proposed sales and/or marketing name to be adopted by the developer should be forwarded to the **street naming and numbering service**, prior to any publication of the site details and sales information.

- 5 If you are aggrieved by the decision of your local planning authority (LPA) to refuse permission for the proposed development or to grant it subject to conditions, then you can appeal to the Secretary of State under section 78 of the Town and Country Planning Act 1990.

If you want to appeal against your local planning authority's decision then you must do so within 6 months of the date of this notice.

However, if an enforcement notice has been served for the same or very similar development the time limit is 28 days from the date of the LPA decision or 28 days from the date the enforcement notice was served.

Appeals can be made online at: <https://www.gov.uk/appeal-planning-decision>

If you are unable to access the online appeal form, please contact the Planning Inspectorate to obtain a paper copy of the appeal form on tel: 0303 444 5000.

The Secretary of State can allow a longer period for giving notice of an appeal, but he will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.

The Secretary of State need not consider an appeal if it seems to him that the local planning authority could not have granted planning permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements, to the provisions of any development order and to any directions given under a development order.

In practice, the Secretary of State does not refuse to consider appeals solely because the local planning authority based their decision on a direction given by him.

6 **Purchase Notices**

If either the local planning authority or the Secretary of State refuses permission to develop land or grants it subject to conditions, the owner may claim that he can neither put the land to a reasonably beneficial use in its existing state nor render the land capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted.

In these circumstances, the owner may serve a purchase notice on the Council (District Council, London Borough Council or Common Council of the City of London) in whose area the land is situated. This notice will require the Council to purchase his interest in the land in accordance with the provisions of Part VI of the Town and Country Planning Act 1990.

- 7 The District Council and County Highway Authority wish to ensure that, in the implementation of the development, hereby approved, the highway verge adjacent to the property is not damaged or does not become unsightly due to the stationing of skips, parking of vehicles, storing of building materials etc thereon. Your attention is, therefore, drawn to the provisions of Section 131 of the Highways Act 1980 and to the Hertfordshire County Council Bylaws 1955 (specifically relating to grass margins and verges in Letchworth Garden City) by virtue of which such actions, unless authorised by the prior grant of a licence, constitute a prosecutable offence. Persons responsible for undertaking the development and any associated works are, therefore, strongly encouraged to take appropriate steps to ensure that no breach of the said legislation occurs during the course of such activities. In the event of any damage being caused it will be expected that suitable reinstatement is undertaken upon completion of the development. Failure to do so could also result in legal action being pursued. To obtain information regarding the issue of licences, contact Hertfordshire Highways, Hertfordshire County Council, County Hall, Pegs Lane, Hertford, SG138DQ or telephone 0300 1234 047.

8 **Cadent Gas Informative:**

Cadent Gas own and operate the gas infrastructure within the area of your development. Contact our Plant Protection Team for approval before carrying out any works on site and ensuring requirements are adhered to. Email plantprotection@cadentgas.com Alternatively you can register on www.beforeyoudig.cadentgas.com This service is free of charge.

THIS PLANNING PERMISSION DOES NOT CONSTITUTE APPROVAL UNDER BUILDING REGULATIONS AND IS NOT A LISTED BUILDING CONSENT OR CONSERVATION AREA CONSENT. IT DOES NOT CONVEY ANY APPROVAL OR CONSENT WHICH MAY BE REQUIRED UNDER ANY ENACTMENT, BYE-LAW, ORDER OR REGULATION OTHER THAN SECTION 57 OF THE TOWN AND COUNTRY PLANNING ACT 1990.