



Mark Youngman
Development Management Group Manager
Hertfordshire County Council
Postal Point CHN115
Farnham House
Six Hills Way
Stevenage
SG1 2ST

Response to Planning application from Hertfordshire County Council (T and CP GDP Order 2015)

Director of Planning

North Hertfordshire Council
Council Offices
Gernon Road
Letchworth Garden City
Hertfordshire
SG6 3JF

District ref: 25/00264/FP
HCC ref: NH/24105/2025
HCC received: 10 April 2025
Area manager: Manjinder Sehmi
Case officer: Paul Marshall

Location

3 TRUEMANS ROAD HITCHIN SG5 2TA

Application type

Full Application

Proposal

AMENDED PROPOSAL

Erection of one self-build semi-detached 2-bed dwelling including bike store, installation of air source heat pump, parking and landscaping
and creation of vehicular access off Truemans Road

Recommendation

Notice is given under article 22 of the Town and Country Planning (Development Management Procedure) (England) Order 2015 that Hertfordshire County Council as Highway Authority does not wish to restrict the grant of permission subject to the following conditions:

CION1) No development shall commence until a Construction Method Statement has been submitted to and approved in writing by the Local Planning Authority, including elements of the CLOCS standards as set out in the Highway Authority's Construction Management template. Thereafter the construction of the development shall only be carried out in accordance with the approved Plan: The Construction Method Statement shall include details of:

Access arrangements to the site.

Construction and storage compounds (including areas designated for car parking, loading / unloading and turning areas).

Cleaning of site entrances, site tracks and the adjacent public highway.

Timing of construction activities (including delivery times and removal of waste) and to avoid school pick up/drop off times. Provision of sufficient on-site parking prior to commencement of construction activities.

Where works cannot be contained wholly within the site a plan should be submitted showing the site layout on the highway including extent of hoarding which must be kept within the site boundary, pedestrian routes and remaining road width for vehicle movements

Reason: In order to protect highway safety and the amenity of other users of the public highway and rights of way in accordance with Policies 5, 12, 17 and 22 of Hertfordshire's Local Transport Plan (adopted 2018).

CON2) Prior to the commencement of the development hereby permitted a plan should be submitted which shows parking details for cars and cycles in accordance with the HCC's Place & Movement Planning Design Guidance (P&MPDG-2023) and in accordance with (Cycle Infrastructure Design' DfT Local Transport Note 1/20 (July 2020) and approved in writing by the Local Planning Authority. Prior to first occupation the approved scheme shall be fully implemented and thereafter retained for this purpose.

Reason: To ensure the provision of adequate cycle and vehicle parking that meets the needs of occupiers of the proposed development and in the interests of encouraging the use of sustainable modes of transport in accordance with Policies 1, 5 and 8 of Hertfordshire's Local Transport Plan (adopted 2018)

HCC as Highway Authority recommends inclusion of the following Advisory Note (AN) to ensure that any works within the highway are carried out in accordance with the provisions of the Highway Act 1980.

AN1) Storage of materials: The applicant is advised that the storage of materials associated with the construction of this development should be provided within the site on land which is not public highway, and the use of such areas must not interfere with the public highway. If this is not possible, authorisation should be sought from the Highway Authority before construction works commence. Further information is available via the County Council website at: <https://www.hertfordshire.gov.uk/services/highways-roads-and-pavements/business-and-developer-information/business-licences/business-licences.aspx> or by telephoning 0300 1234047.

AN2) Obstruction of highway: It is an offence under section 137 of the Highways Act 1980 for any person, without lawful authority or excuse, in any way to wilfully obstruct the free passage along a highway or public right of way. If this development is likely to result in the public highway or public right of way network becoming routinely blocked (fully or partly) the applicant must contact the Highway Authority to obtain their permission and requirements before construction works commence. Further information is available via the County Council website at: <https://www.hertfordshire.gov.uk/services/highways-roads-and-pavements/business-and-developer-information/business-licences/business-licences.aspx> or by telephoning 0300 1234047.

AN3) Debris and deposits on the highway: It is an offence under section 148 of the Highways Act 1980 to deposit compost, dung or other material for dressing land, or any rubbish on a made up carriageway, or any or other debris on a highway to the interruption of any highway user. Section 149 of the same Act gives the Highway Authority powers to remove such material at the expense of the party responsible. Therefore, best practical means shall be taken at all times to ensure that all

vehicles leaving the site during construction of the development and use thereafter are in a condition such as not to emit dust or deposit mud, slurry or other debris on the highway. Further information is available by telephoning 0300 1234047.

AN4) Gravel / shingle driveways: Where loose gravel or shingle is used, a suitable measure to prevent material spilling onto the road/footpath/verge must be installed. It is an offence under section 148 of the Highways Act 1980 to deposit debris onto the public highway, and section 149 of the same Act gives the Highway Authority powers to remove such material at the expense of the party responsible. Further information is available by telephoning 0300 1234047.

AN5) Avoidance of surface water discharge onto the highway: The applicant is advised that the Highway Authority has powers under section 163 of the Highways Act 1980, to take appropriate steps where deemed necessary (serving notice to the occupier of premises adjoining a highway) to prevent water from the roof or other part of the premises falling upon persons using the highway, or to prevent so far as is reasonably practicable, surface water from the premises flowing on to, or over the footway of the highway.

AN6) New or amended vehicle crossover access (section 184): Where works are required within the public highway to facilitate a new or amended vehicular access, the Highway Authority require the construction of such works to be undertaken to their satisfaction and specification, and by a contractor who is authorised to work in the public highway. If any of the works associated with the construction of the access affects or requires the removal and/or the relocation of any equipment, apparatus or structures (e.g. street name plates, bus stop signs or shelters, statutory authority equipment etc.) the applicant will be required to bear the cost of such removal or alteration. Before works commence the applicant will need to apply to the Highway Authority to obtain their permission, requirements and for the work to be carried out on the applicant's behalf. Further information is available via the County Council website at: <https://www.hertfordshire.gov.uk/services/highways-roads-and-pavements/changes-to-your-road/dropped-kerbs/dropped-kerbs.aspx> or by telephoning 0300 1234047.

COMMENTS

The proposals are amended and include erection of one self-build semi-detached 2-bed dwelling including bike store, installation of air source heat pump, parking and landscaping and creation of vehicular access off Trueman's Road.

CONTEXT

Context: Trueman Road is an unclassified local access road and provides a local access function in the road hierarchy. Trueman Road is highway maintainable at public expense. A 30mph speed limit applies. on HCC's Place and Movement network Trueman Road is classed as P2/M1 (e.g. Residential Street). No reportable highway accidents recorded within the immediate vicinity of the application site (5-year rolling). No Public Right of Way (as shown on the PRoW map) directly affects the site or would be affected by the proposal. The county council considers Trueman Road not to be a traffic sensitive road.

Policy Review:

The key documents used to assess the application are

- Manual for Streets 2007
- National Planning Policy Framework (July 2021)

- Hertfordshire County Council's (HCC) Local Transport Plan-4 [2018-2031, May2018]
- Cycle Infrastructure Design DfT Local Transport Note 1/20 (July 2020)
- HCC's Place & Movement Planning Design Guidance (adopted in March 2024)

PLANNING HISTORY

The application site has previous planning history with 21/00381/FP. Please note since 2021 there have been changes to our policy on dropped kerbs and on parking spaces.

DRAWINGS

The Highway Authority note the submission of materials in support of the planning application, including drawing numbers: OAK-351-PL0-01, OAK-351-PL0-01A, and Design and Access Statement.

ACCESSIBILITY

'Cycle Infrastructure Design' DfT Local Transport Note 1/20 (July 2020) recommends for cycle parking storage should be 2m (1.8m is acceptable) in length by 0.3m space between cycles. There should be parking for 1 cycle per dwelling. Outside cycle parking should be covered and lockable. The provision of well-located, safe and secure cycle parking for residents and visitors is a key factor in encouraging people to cycle as an alternative to using the private car. Drawing Ref (OAK-351-PL0-01A) illustrates the cycle store is in accord with the above standard.

PARKING

The LPA shall be responsible for assessing the proposed development against local parking standards and to satisfy for itself that any level of parking it requires can be achieved within the boundary of the site and not overhang the highway, including the highway footway / grass verge / vehicle crossover. The Highway Authority would observe the following, the parking bays are not in accordance with HCC's Place and Movement Planning Design Guide (P&MPDG) (Part 3 Chapter 1 page 35). Please see Condition 2 above.

ACCESS

Residential Dropped Kerb Policy states: Dropped kerbs will be no wider than four flat kerbs. (each kerb is .90 in length) This is the widest dropped kerb that we will allow. You will also be provided with one or two ramped kerbs depending on your property. Please do not apply for a dropped kerb wider than this as it will be refused.

VISIBILITY

Drawing Ref (OAK-351-PL0-01) illustrates vehicle-to-vehicle inter-visibility and pedestrian visibility have an acceptable level of visibility and accords with the principles found in Hertfordshire's Place & Movement Planning Design Guide Part 4 Chapter 6 section 18.1, page 70.

EMERGENCY ACCESS

The nature of the site puts the proposals / access within 45 meters from the public highway (As required in accordance with MfS 6.7.2)

REFUSE / RECYCLING

The proposals for recycling bin storage must be in line with Manual for Streets MfS 6.8.9 residents should not be required to carry waste more than 30m and be within 25m of the kerbside/bin collection point.

CONSTRUCTION METHOD STATEMENT

It is important that a CMS is provided considering the nature of the residential area. The statement must have or be shown as a drawing of the construction site and the dedicated areas within. Contractor parking must take account of the required residential parking along the carriageway. The applicant must ensure no residents are prevented from parking their vehicles. See Condition 1 above.

CONCLUSION

Should the LPA be minded to approve the application please note the above conditions and informatives. This level of development is unlikely to generate any extra movements which would ultimately lead to demonstrable harm to the highway network in terms of free flow and capacity, therefore; the highway authority would not wish to restrict the grant of planning permission.

Signed

Paul Marshall

29 April 2025