



Planning Applications – Anglian Water Objection

If you would like to discuss any of the points in this document please contact us on 07929 786955 or email planningliaison@anglianwater.co.uk.

AW Site Reference: 221782/1/0230904

Local Planning Authority: North Hertfordshire District

Site: Guysfield Residential Home Willian Road
Letchworth Garden City Hertfordshire SG6 2AB

Proposal: Redevelopment of existing care home and erection of detached 3 to 4 storey 70-bed residential nursing home (Class C2 use) with associated parking, landscaping, amenities and works, following demolition of extensions to existing care home.

Planning application: 24/02758/FP

Prepared by: Pre-Development Team

Date: 18 August 2025

ASSETS

Section 1 - Assets Affected

Our records show that there are no assets owned by Anglian Water or those subject to an adoption agreement within the development site boundary.

WASTEWATER SERVICES

Section 2 - Wastewater Treatment

When assessing the receiving water recycling centre's (WRC) dry weather flow (DWF) headroom we take the latest DWF figures, as verified by the Environment Agency and add to this, sites with planning consent. Based on the above assessment Letchworth WRC is within the acceptance parameters and can accommodate the flows from the proposed growth.

TAL

Letchworth Water Recycling Centre is included in our nutrient removal programme and will be designed to technically achievable limits (TAL). For the majority of WRCs in this programme this will be for phosphorous removal where TAL is 0.25mg/l. When both TAL and DWF capacity constraints are forecast at a WRC, either due to housing/non-domestic growth or infiltration into the network then alternative options will need to be considered.

Some WRCs will be either too remote or not near another WRC with capacity. The impact of environmental pressures, including sites at technical achievable limits, and the approach required to enable future sustainable growth is something we will continue to discuss with the Environment Agency and key stakeholders, including local planning authorities.

Where TAL impacts on the DWF headroom and our ability to accommodate future growth we may start objecting, if we are not doing so already, to planning applications in the impacted catchments.

Section 3 - Used Water Network

This response has been based on the following submitted documents:

213692-CCL-XX-00-01000 Site: Date of Report: 24th July 2025 Revision: P05

The sewerage system at present has available capacity for the anticipated foul flows. If the developer wishes to connect to our sewerage network they should serve notice under Section 106 of the Water Industry Act 1991. We will then advise them of the most suitable point of connection.

1. INFORMATIVE

- Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087 Option 2.

2. INFORMATIVE - Protection of existing assets - A public sewer is shown on record plans within the land identified for the proposed development. It appears that development proposals will affect existing public sewers. It is recommended that the applicant contacts Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers will not be permitted (without agreement) from Anglian Water.

3. INFORMATIVE - Building near to a public sewer - No building will be permitted within the statutory easement width of 3 metres from the pipeline without agreement from Anglian Water. Please contact Development Services Team on 0345 606 6087 Option 2.

4. INFORMATIVE: The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 Option 2 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements.

Section 4 - Surface Water Disposal

Anglian Water object to this application as there connection to the public sewerage network is still being proposed without full and complete hierarchy evidence.

Infiltration is proposed as well as connection to a public sewer. Anglian Water will only consider a connection to a public sewer when full evidence to discount all other methods if surface water disposal are presented. If the applicant believes the surface water hierarchy has been fully explored, they will need to engage with us and provide evidence that all other options have been exhausted and discounted in line with the Surface Water Hierarchy and with consultation with the LLFA. Only when this engagement has taken place and an agreement issued by Anglian Water will we remove any objections.

<https://www.anglianwater.co.uk/developing/drainage-services/sustainable-drainage-systems/surface-water-policy/>

