

IF IN DOUBT ASK

THIRD ANGLE PROJECTION

- NOTES
1. REMOVE ALL BURRS & SHARP EDGES.
 2. DO NOT SCALE IF IN DOUBT ASK.
 3. WELDING SYMBOLS ARE TO BS EN ISO 22553:2019
 4. MATERIAL: CHS TO BS EN 10210 OR EN 10219 GRD S275 WITH A TENSILE STRENGTH OF 430N/mm² OR GRD S355 WITH A TENSILE STRENGTH OF 490N/mm². PLATE FROM M.S TO BSEN 10025 GRD S355. PLATE 25mm THICK AND OVER TO BE CHARPY TEST VALUE OF 27J (MIN) AT -20°C.
 5. FINISH: HOT DIP GALV TO BS EN ISO 1461.
 6. BASE COMPARTMENT IS FITTED WITH 12mm THK. TIMBER BASEBOARD MEASURING 610 X 90 AND A M8 EARTHING SET DOOR OPENING MEASURES 600 X 115 AND IS COVERED BY A 2mm THK. PRESSED STEEL DOOR COVER SECURED BY A TRIANGULAR HEADED ST. ST. SCREW.
 7. CABLE ENTRY SLOT MEASURES 160x75 AND IS 350 BELOW GROUND LEVEL.
 8. ALL TIMBER COMPONENTS TO BE SADOLIN COATED.
 9. FOR COLUMN JOINT & SPIGOT DETAIL SEE DRG. C201-126-2
 10. FOR DETAIL OF BASE COMPARTMENT & SPIGOT SEE DRG C201-7-2

