

Hertfordshire County Council

Proposed Connection Schedule

06 July 2026

St Lppolyts - S38 Proposed Lighting - Equipment Schedule - R1

Proposed Unit No.	Easting Coordinates	Northing Coordinates	Service Connection Type	Location	Unit Description	Isolator Type	Termination Type
NC01	519380.08	226907.55	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC02	519358.87	226887.33	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC03	519330.02	226875.22	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC04	519304.00	226858.64	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC05	519276.41	226830.13	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC06	519258.44	226802.74	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC07	519263.03	226783.22	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC08	519231.03	226810.38	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC09	519182.31	226766.81	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC10	519193.91	226785.62	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC11	519200.47	226809.92	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC12	519195.42	226829.53	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting raise & lower column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC13	519167.55	226841.10	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC14	519153.87	226818.55	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC15	519126.97	226804.33	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC16	519123.74	226817.85	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting column with post top mounted Urbis Axia 3.1 5418 8 OSLON SQUARE GIANT Drv 700mA NW 740 18.3W 567902 2.64klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC17	519276.83	226788.03	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting raise & lower column with post top mounted Urbis Axia 3.1 5383 8 OSLON SQUARE GIANT 300mA NW 740 8.4W 487492 1.16klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC18	519245.38	226808.76	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting raise & lower column with post top mounted Urbis Axia 3.1 5383 8 OSLON SQUARE GIANT 300mA NW 740 8.4W 487492 1.16klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC19	519213.45	226824.45	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting raise & lower column with post top mounted Urbis Axia 3.1 5383 8 OSLON SQUARE GIANT 300mA NW 740 8.4W 487492 1.16klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC20	519151.69	226852.34	Proposed Double Pole DNO Supply Connection	MMA19973/001	Proposed 6m Hertfordshire County Council specification lighting raise & lower column with post top mounted Urbis Axia 3.1 5383 8 OSLON SQUARE GIANT 300mA NW 740 8.4W 487492 1.16klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply

NOTE: NUMBERS SHOWN ON THE SCHEDULE AND DESIGN DRAWING ARE FOR IDENTIFICATION PURPOSES ONLY - ACTUAL COLUMN NUMBERS TO BE SPECIFIED BY LOCAL AUTHORITY LIGHTING DEPARTMENT OR OVERSEEING ORGANISATION.