

DRAWING NOTES

- THIS DRAWING IS THE COPYRIGHT OF QODA CONSULTING AND SHALL NOT BE COPIED OR REPRODUCED WITHOUT PRIOR EXPRESS PERMISSION.
- MATERIALS AND WORKMANSHIP SHALL BE TO THE BEST OF THEIR RESPECTIVE KIND AND CONFORM WITH THE RELEVANT BRITISH & EUROPEAN STANDARDS. SPECIFICATIONS CISE COMMISSIONING CODES, IET REGULATIONS AND CODES OF PRACTICE.
- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS AND THE SERVICES SPECIFICATION DOCUMENT(S).
- ALL DIMENSIONS ARE IN MILLIMETERS, UNLESS OTHERWISE STATED.
- REFER TO THE ARCHITECT'S DRAWINGS FOR SETTING OUT.
- DO NOT SCALE FROM THIS DRAWING.
- CARRY WITH THE ENGINEER PRIOR TO ORDERING OR PUTTING WORK IN HAND ANY DISCREPANCIES BETWEEN PROJECT SPECIFICATION(S), DRAWINGS, SCHEDULES, E
- REFER TO THE ARCHITECT'S DRAWINGS FOR DETAILS OF ALL BUILDING FIRE COMPARTMENTATION AND FIRE SEPARATION.
- FIRE SEAL ALL PENETRATIONS THROUGH FIRE RATED CONSTRUCTION.
- USE BUILDING CONTROL APPROVED DETAILS TO THE FIRE RATING OF THE BARRIER/COMPARTMENT.
- THE ELECTRICAL CONTRACTOR SHALL INCLUDE FOR ALL MODIFICATIONS TO THE EXISTING LIGHTING CONTROL SYSTEM WITH ANY NECESSARY ALTERATIONS TO SUIT THE NEW LIGHTING LAYOUT.

LEGEND

- PIR S

PIR F

W1

W1/E

L2

L2/E

L1

L1/E

SD

MANUAL CALL POINT

PIR PRESENCE DETECTOR (SURFACE)

PIR PRESENCE DETECTOR (FLUSH)

WALL MOUNTED LUMINAIRE

WALL MOUNTED LUMINAIRE (EMERGENCY)

CEILING MOUNTED LUMINAIRE

CEILING MOUNTED LUMINAIRE (EMERGENCY)

LINEAR BATTEN

LINEAR BATTEN (EMERGENCY)

SMOKE DETECTOR

MANUAL CALL POINT



P02	S3 - FOR REVIEW AND COMMENT	23.01.25
P01	S3 - FOR REVIEW AND COMMENT	01.11.24
Rev:	Description:	Date:



Client:

North Hertfordshire District Council

Project:

NHDC Decarbonisation Scheme - Royston Leisure Centre

Drawing Title:
Electrical Services

Ground Floor Proposed Lighting Layout

Status:	Stage:	Job Number:
S3 - FOR REVIEW AND COMMENT	4	CM1056
Designed:	Drawn:	Checked:
TG	AG	VS
Drawing Number:	Scale:	Paper Size:
RLC-QDD-XX-00-D-E-00501	1:100	A0
Rev:	Rev:	
	P03	