

NORTH HERTS COUNCIL

MEMORANDUM

To: PLANNING CONTROL AND CONSERVATION Ben Glover	From: ENVIRONMENTAL HEALTH Alan Stone Ext 4108
	Date: 23 rd September 2025
Our Ref: 6395/25	Your : 25/02064/OP Ref:
Subject: Outline Application: Erection of up to 50 dwellings including affordable housing, together with amenity space, landscaping and all associated infrastructure and works (all matters reserved except means of access). Land Adjacent To 10, Hambridge Way, Pirton, Hertfordshire	

Comments:

Thank you for consulting Environmental Protection on this outline application. I have reviewed the submitted information and can respond as follows.

Noise (and other nuisances):

The application is supported by a noise assessment which concludes that, subject to the inclusion of appropriate glazing and ventilation, there is no reason on acoustic grounds to refuse permission. I am satisfied with this and, as recommended by the acoustic assessment, have no objections subject to the following condition being placed on any decision notice, should you be minded to grant approval.

Prior to the commencement of development a scheme shall be submitted for the protection of the dwellings from noise for approval in writing by the Local Planning Authority. The scheme shall be in accordance with the recommendations stated in the Cass Allen Ltd report (Ref: RP01-25395-R0) dated 12th August 2025. No dwellings shall be occupied until the scheme providing protection for those dwellings has been implemented in accordance with the approved details. The approved scheme shall be retained in accordance with those details thereafter.

Local Air Quality:

Given the scale of the development, I recommend that a Construction Environmental Management Plan to deal with noise and dust impacts (among other matters) during the construction phase is secured via a suitably worded condition.

North Herts Council have specific air quality planning guidance that can be found at <http://www.north-herts.gov.uk/home/environmental-health/pollution/air-quality/air-quality-and-planning>

Application of the guidance to a development of this scale and location defines the site as being a MINOR scale development and so the following conditions are recommended to ensure that appropriate local air quality mitigation is provided.

EV Recharging Infrastructure Condition

Prior to occupation, each of the proposed new dwellings shall incorporate an Electric Vehicle (EV) ready domestic charging point. EV charge points shall be allocated to any visitor parking on a ratio of 1 charge point per 10 visitor parking spaces.

Reason: To contribute to the objective of providing a sustainable transport network and to provide the necessary infrastructure to help off-set the adverse impact of the operational phase of the development on local air quality.

Informative

1) EV Charging Point Specification:

A charging point shall be installed by an appropriately certified electrician/electrical contractor in accordance with the following specification. The necessary certification of electrical installation should be submitted as evidence of appropriate installation to meet the requirements of Part P of the most current Building Regulations.

Cable and circuitry ratings should be of adequate size to ensure a minimum continuous current demand for the vehicle of 16A and a maximum demand of 32A (which is recommended for Eco developments)

- A separate dedicated circuit protected by an RBCO should be provided from the main distribution board, to a suitably enclosed termination point within a garage or an accessible enclosed termination point for future connection to an external charge point.
- The electrical circuit shall comply with the Electrical requirements of BS7671: 2008 as well as conform to the IET code of practice on Electric Vehicle Charging Equipment installation 2012 ISBN 978-1-84919-515-7 (PDF). This includes requirements such as ensuring the Charging Equipment integral protective device shall be at least Type A RCD (required to comply with BS EN 61851 Mode 3 charging).
- If installed in a garage all conductive surfaces should be protected by supplementary protective equipotential bonding. For vehicle connecting points installed such that the vehicle can only be charged within the building, e.g. in a garage with a (non-extended) tethered lead, the PME earth may be used. For external installations the risk assessment outlined in the IET code of practice must be adopted, and may require additional earth stake or mat for the EV charging circuit. This should be installed as part of the EV ready installation to avoid significant on cost later.
- A list of authorised installers (for the Government's Electric Vehicle Homecharge Scheme) can be found at <https://www.gov.uk/government/organisations/office-for-low-emission-vehicles>

- UK Government issued legislation in 2021 to require domestic EV charge points to be smart, thus we recommend that all charge points will be capable of smart charging, as detailed in UK Gov regulations.

1) The above condition is considered relevant and reasonable for the following reasons:

- Paragraphs 170 (e), 181 of the NPPF, which refer to the effects (including cumulative effects) of pollution (including air pollution) on health, the natural environment (including air quality).
- Paragraphs 102 (d), 105 (e) and 110 (e) of the NPPF, which refer to the need to promote sustainable transport including the provision for charging plug-in and other ultra low emission vehicles.
- HCC Local Transport Plan (LTP4) 2018-2031 which includes an objective to 'preserve the character and quality of the Hertfordshire environment' and 'make journeys and their impact safer and healthier', as well as its Emissions Reduction Policy 19.
- It is consistent with the approach specified in the NHDC Air Quality Planning Guidance Document, which is referenced within the current consultation version of the Local Plan.

Land contamination:

The application is also supported by a land contamination report comprising a preliminary study and a ground investigation. The report concludes that there is a low or very low risk of contamination which will impact any future users of the site. I am satisfied with this conclusion, based on the submitted information, but recommend the following condition is placed on any decision notice should you be minded to grant approval.

Any contamination that is found during the course of construction of the development permitted that was not previously identified shall be reported immediately to the local planning authority. Development on the part of the site affected shall be suspended and a risk assessment carried out and submitted to and approved in writing by the local planning authority. Where unacceptable risks are found remediation and verification schemes shall be submitted to and approved in writing by the local planning authority. These approved schemes shall be implemented prior to the development being resumed or continued.

Regards
Alan Stone