

FOUNDATION DEPTHS  
ALL FOUNDATION DEPTHS ARE TO BE 1.05m MIN FROM EXISTING GROUND LEVEL  
TREES ARE CALCULATED AT MATURE HEIGHT IN HIGH SHRINKAGE SOIL  
USING NHBC STANDARDS (CHAPTER 4.2) THEREFORE INVERTS MAY  
BE HIGHER THAN STATED.  
ALL EXCAVATIONS TO BE CHECKED BY BUILDING INSPECTOR  
PRIOR TO POURING CONCRETE  
TREE SPECIES AND POSITIONS TO BE CHECKED ON SITE PRIOR TO COMMENCEMENT  
AND AGREED WITH THE BUILDING INSPECTOR

HORSE CHESTNUT TREE  
(FOUNDATION 1.05m DEEP)

A PORCH ADDED 05/AUG/25

HOWARD'S WOOD

