

DELEGATED FILE NOTE

CASE OFFICER: ...Harriet Sanders.....

APPLICATION REFERENCE	BRIEF DESCRIPTION OF DEVELOPMENT	APPLICATION SITE
24/01550/LDCP	Single storey infill and rear extension. Insertion of rear dormer window to create additional habitable loft space	5 Upper Green Ickleford Hitchin Hertfordshire SG5 3YG

Submitted Plan Nos

1.0 Policies

1.0 Policies

1.1 N/A

2.0 Site History

2.1 None relevant.

2.2 Permitted development rights do not appear to have been removed.

3.0 Representations

n/a

4.0 Planning Considerations

4.1 Site and Surroundings

4.1.1 No 5 is a mid terrace, two storey dwelling in the conservation area.

4.2 Proposal

4.2.1 A certificate of lawfulness (proposed) is sought for “Single storey infill and rear extension. Insertion of rear dormer window to create additional habitable loft space.”

4.3 Key Issues

4.3.1 The key issues for consideration are whether the proposed development would require a specific planning permission or be considered ‘permitted development’ in line with the Town and Country Planning (General Permitted Development) Order 2015, Schedule 2, Part 1 Class A and Class B.

Class A – The enlargement, improvement or other alteration of a dwellinghouse.

A.1 Development is not permitted by Class A if—

(a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class G, M, MA, N, P, PA or Q of Part 3 of this Schedule (changes of use);

The proposal complies with this criterion.

(b) as a result of the works, the total area of ground covered by buildings within the curtilage of the dwellinghouse (other than the original dwellinghouse) would exceed 50% of the total area of the curtilage (excluding the ground area of the original dwellinghouse);

The proposal complies with this criterion.

(c) the height of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the highest part of the roof of the existing dwellinghouse;

The proposal complies with this criterion.

(d) the height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse;

The proposal complies with this criterion.

(e) the enlarged part of the dwellinghouse would extend beyond a wall which—

(i) forms the principal elevation of the original dwellinghouse; or

(ii) fronts a highway and forms a side elevation of the original dwellinghouse;

The proposal meets this criterion.

(f) subject to paragraph (g), the enlarged part of the dwellinghouse would have a single storey and—

(i) extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse, or

(ii) exceed 4 metres in height;

The proposed development complies with these criteria.

g) for a dwellinghouse not on article 2(3) land nor on a site of special scientific interest, the enlarged part of the dwellinghouse would have a single storey and—

(i) extend beyond the rear wall of the original dwellinghouse by more than 8 metres in the case of a detached dwellinghouse, or 6 metres in the case of any other dwellinghouse, or

(ii) exceed 4 metres in height;

N/a.

(h) the enlarged part of the dwellinghouse would have more than a single storey

and—

(i) extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or

(ii) be within 7 metres of any boundary of the curtilage of the dwellinghouse being enlarged which is opposite the rear wall of that dwellinghouse;

N/a.

(i) the enlarged part of the dwellinghouse would be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would exceed 3 metres;

The proposal complies with this criterion.

(j) the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse, and would—

(i) exceed 4 metres in height,

(ii) have more than a single storey, or

(iii) have a width greater than half the width of the original dwellinghouse;

The proposal complies with this criterion.

(ja) any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (e) to (j);

N/a.

(k) it would consist of or include—

(i) the construction or provision of a verandah, balcony or raised platform,

(ii) the installation, alteration or replacement of a microwave antenna,

(iii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or

(iv) an alteration to any part of the roof of the dwellinghouse.; or

The proposal fails this criterion as alterations to the roof are proposed. However, see Class B assessment below.

(l) the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses).

N/a

A.2 In the case of a dwellinghouse on article 2(3) land, development is not permitted by Class A if—

(a) it would consist of or include the cladding of any part of the exterior of the dwellinghouse with stone, artificial stone, pebble dash, render, timber, plastic or tiles;

(b) the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse; or

(c) the enlarged part of the dwellinghouse would have more than a single storey and extend beyond the rear wall of the original dwellinghouse.

(d) any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (b) and (c).

The proposal is in a conservation area. The infill extension would extend beyond a side wall. The proposal therefore criterion fails this criterion sub section (b).

Conditions A.3

Development is permitted by Class A subject to the following conditions—

(a) the materials used in any exterior work (other than materials used in the construction of a conservatory) must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

The submitted plans show a glass lean to style roof on the infill extension. This is not of a similar appearance to the materials of the main dwelling. The proposal therefore fails to meet this condition.

(b) any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse must be—

(i) obscure-glazed, and

(ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed; and

N/a

(c) where the enlarged part of the dwellinghouse has more than a single storey, or forms an upper storey on an existing enlargement of the original dwellinghouse, the roof pitch of the enlarged part must, so far as practicable, be the same as the roof pitch of the original dwellinghouse.

N/a

Class B. The enlargement of a dwellinghouse consisting of an addition or alteration to its roof.

B.1. Development is not permitted by Class B if—

(a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class G, M, MA, N, P, PA or Q of Part 3 of this Schedule (changes of use);

The proposal complies with this criterion.

(b) any part of the dwellinghouse would, as a result of the works, exceed the height of the highest part of the existing roof;

The proposal complies with this criterion.

(c) any part of the dwellinghouse would, as a result of the works, extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway;

The proposal complies with this criterion.

(d) the cubic content of the resulting roof space would exceed the cubic content of the original roof space by more than—

(i) 40 cubic metres in the case of a terrace house, or

(ii) 50 cubic metres in any other case;

The property is a terrace house. The proposed cubic content does not exceed 40 cubic metres. The proposal therefore complies with this criterion.

(e) it would consist of or include—

(i) the construction or provision of a verandah, balcony or raised platform, or

(ii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe;

None of the above apply. The proposal therefore meets this criterion.

(f) the dwellinghouse is on article 2(3) land

The application site is within article 2(3) land. The proposal therefore fails this criterion.

(g) the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses).; or

n/a.

(h) the existing dwellinghouse has been enlarged in reliance on the permission granted by Class AA (enlargement of a dwellinghouse by construction of additional storeys).

n/a.

Conditions

B.2. Development is permitted by Class B subject to the following conditions—

(a) the materials used in any exterior work shall be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

The proposed materials are not specified. This condition is therefore not met.

(b) the enlargement shall be constructed so that—

(i) other than in the case of a hip-to-gable enlargement or an enlargement which joins the original roof to the roof of a rear or side extension —

(aa) the eaves of the original roof are maintained or reinstated; and

(bb) the edge of the enlargement closest to the eaves of the original roof shall, so far as practicable, be not less than 20 centimetres from the eaves, measured along the roof slope from the outside edge of the eaves;

and

(ii) other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement extends beyond the outside face of any external wall of the original dwellinghouse; and

The proposal complies with this condition.

(c) any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse shall be—

(i) obscure-glazed, and

(ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.

No side windows are proposed. The proposed development complies with this condition.

4.4.1 Certificate of Lawfulness (proposed) cannot be issued on the basis that the proposed development fails to comply with criterion A.2 (b) or meet condition A.3 (a) of Class A , fails to comply with criterion B.1 (f) or meet condition B.2 (a) of Class B, Part 1 of Schedule 2 of the Town and Country Planning (General Permitted Development) (England) Order 2015 as amended and is not, therefore, permitted development.

Signed  Melissa Tyler	Development Management North Hertfordshire District Council Council Offices Gernon Road Letchworth Herts SG6 3JF
Determining Officer Date: 18 September 2024	