

Item	Description of Clearance	Minimum Clearance (metre) at 400kV
1	To Ground	7.6
2	To Normal Road Surface	8.1
3	To road surface of designated 15 metres high load roads	9.2
4	To motorway or other road surface where "skyscraper" can be used	10.5
5	To motorway road surface where scaffolding is to be used	16.3
	(i) Normal 3 lane motorways	13.3
	(ii) Elevated 2 lane motorways	
6	To any object/building on which a person may stand including ladders, access platform, etc.	5.3
7	To any object to which access is not required AND on which a person cannot stand or lean a ladder	3.1
8	To trees under or adjacent to line and (i) Unable to support ladder climber (ii) Capable of supporting ladder climber	3.1 5.3
9	(a) Trees falling towards line with line conductors hanging vertically only (b) Trees falling towards line with line conductors hanging vertically only	3.1 5.3
10	To trees in orchards and pop gardens	5.3
11	To irrigators, slurry guns and high pressure hoses	30.0
12	To street lighting standards with: (a) Standard normal upright position (b) Standard falling towards line with line conductors hanging vertically only (c) Standard falling towards line only	4.0 4.0 1.0

Clearance at 400KV Displayed

[illegible]

6.0 m Horiz. Scale

2.5 m Vert. Scale