



Planning Applications – Suggested Informative Statements and Conditions Report

If you would like to discuss any of the points in this document please

[\[REDACTED\]
planningliaison@anglianwater.co.uk](mailto:planningliaison@anglianwater.co.uk)

AW Site 214567/1/0210000
Reference:

Local North Hertfordshire District
Planning
Authority:

Site: Land Surrounding Burloes Cottages
Newmarket Road Royston Hertfordshire

Proposal: Hybrid application for residential
development of up to 325 dwellings
comprising (a) full planning application for
Phase 1 comprising 102 dwellings and
associated infrastructure including access
from Newmarket Road, emergency and
pedestrian/cycle acc

Planning 24/01013/OP
application:

Prepared by: Pre-Development Team

Date: 3 June 2024

ASSETS

Section 1 - Assets Affected

Our records show that there are no assets owned by Anglian Water or those subject to an adoption agreement within the development site boundary.

WASTEWATER SERVICES

Section 2 - Wastewater Treatment

The foul drainage from this development is in the catchment of Royston Water Recycling Centre that will have available capacity for these flows

When assessing the receiving water recycling centre's (WRC) dry weather flow (DWF) headroom we take an average flow over the past 5 years to take account of changing weather patterns. Where the average exceeds the WRC's permitted allowance we also take account of the following Environment Agency enforcement trigger - "has the DWF permit been exceeded in 3 of the last 5 years" – this must include non-compliance from the last annual data return. Based on the above assessment Royston WRC is within the acceptance parameters and can accommodate the flows from the proposed growth.

Section 3 - Used Water Network

This response has been based on the following submitted documents: FRA 2307-871 Nov 2023 The sewerage system at present has available capacity for these flows. If the developer wishes to connect to our sewerage network they should serve notice under Section 106 of the Water Industry Act 1991. We will then advise them of the most suitable point of connection. 1. INFORMATIVE - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087. 2. INFORMATIVE - Protection of existing assets - A public sewer is shown on record plans within the land identified for the proposed development. It appears that development proposals will affect existing public sewers. It is recommended that the applicant contacts Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers will not be permitted (without agreement) from Anglian Water. 3. INFORMATIVE - Building near to a public sewer - No building will be permitted within the statutory easement width of 3 metres from the pipeline without agreement from Anglian Water. Please contact Development Services Team on 0345 606 6087. 4. INFORMATIVE: The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements.

Section 4 - Surface Water Disposal

The preferred method of surface water disposal would be to a sustainable drainage system (SuDS) with connection to sewer seen as the last option. Building Regulations (part H) on Drainage and Waste Disposal for England includes a surface water drainage hierarchy, with infiltration on site as the preferred disposal option, followed by discharge to watercourse and then connection to a sewer.

From the details submitted to support the planning application the proposed method of surface water management does not relate to Anglian Water operated assets. As such, we are unable to provide comments in the suitability of the surface water management. The Local Planning Authority should seek the advice of the Lead Local Flood Authority or the Internal Drainage Board. The Environment Agency should be consulted if the drainage system directly or indirectly involves the discharge of water into a watercourse. Should the proposed method of surface water management change to include interaction with Anglian Water operated assets, we would wish to be re-consulted to ensure that an effective surface water drainage strategy is prepared and implemented.