

HOUSE 4 — HOUSE 5

Unit 4


Bedroom 3 has a high level skylight but no window.
A window is required for a fire exit and for aspect.

Unguarded opening at 0.7m from floor

Bedroom 2 has no window or skylight


Bedroom 3 requires skylight for ventilation

Bedroom 4 requires low window for fire egress and aspect




Justification for change of roof pitch

Scale 1 : 100 at A3 Sheet Size




SECTION YY


SECTION YY



HOUSE 4 — HOUSE 5



SECTION W W



SECTION X X

Revised Design for Conversion of
Existing Listed Barns and Proposed
Four Barn Style Dwellings with
Covered Parking and Associated
Works at Site West of Lordship
Farmhouse, Pirton Road, Holwell
Hertfordshire

Ivan J. Clarke & John W. Barrett
Hall Farm East, Letchworth Lane
Letchworth Garden City
Hertfordshire SG6 3NH
Tel. 01462 685251
e-mail johnandivan@btconnect.com

REVISION 'A' MAY 2026
Amended Elevational Detailing
to all Six Dwellings

Scale 1 : 100
Date : Feb.2025
Ref. W325A

25A

