NORTH HERTFORDSHIRE DISTRICT COUNCIL

Town and Country Planning Act 1990
Town and Country Planning (General Development Procedure) Order 2015

DECISION NOTICE

Correspondence Address:
Clarke & Whalen Architects Ltd.
28-30 Coldharbour Lane
Harpenden
AL5 4UN

Applicant:
S Thompson

PARTICULARS OF DEVELOPMENT

Application:	18/00349/FP
Proposal:	Erection of 3 x 3 bed detached dwellings with associated road and landscaping following demolition of existing house and outbuildings
Location:	White Cottage, Park Lane, Kimpton, Hitchin, Hertfordshire, SG4 8EG
Plan Nos:	5353/01A 5354/10D 5354/07C 5354/08A 5354/09C

PARTICULARS OF DECISION

In pursuance of its powers under the above Act and the associated Orders and Regulations, the Council hereby **GRANT PERMISSION** for the development proposed by you in your application received with sufficient particulars on 2 February 2018, subject to the following condition(s):

1. The development hereby permitted shall be begun before the expiration of 3 years from the date of this permission.

   Reason: To comply with the provisions of Section 91 of the Town and Country Planning Act 1990 as amended by Section 51 of the Planning and Compulsory Purchase Act 2004.

2. The development hereby permitted shall be carried out wholly in accordance with the details specified in the application and supporting approved documents and plans listed above.

Reason: To ensure the development is carried out in accordance with details which form the basis of this grant of permission.

3. (a) No development approved by this permission shall be commenced prior to the submission to, and agreement of the Local Planning Authority of a written preliminary environmental risk assessment (Phase I) report containing a Conceptual Site Model that indicates sources, pathways and receptors. It should identify the current and past land uses of this site (and adjacent sites) with view to determining the presence of contamination likely to be harmful to human health and the built and natural environment.
(b) If the Local Planning Authority is of the opinion that the report which discharges condition (a), above, indicates a reasonable likelihood of harmful contamination then no development approved by this permission shall be commenced until a Site Investigation (Phase II environmental risk assessment) report has been submitted to and approved by the Local Planning Authority which includes:

(i) A full identification of the location and concentration of all pollutants on this site and the presence of relevant receptors, and;
(ii) The results from the application of an appropriate risk assessment methodology.

(c) No development approved by this permission (other than that necessary for the discharge of this condition) shall be commenced until a Remediation Method Statement report; if required as a result of (b), above; has been submitted to and approved by the Local Planning Authority.

(d) This site shall not be occupied, or brought into use, until:

(i) All works which form part of the Remediation Method Statement report pursuant to the discharge of condition (c) above have been fully completed and if required a formal agreement is submitted that commits to ongoing monitoring and/or maintenance of the remediation scheme.
(ii) A Remediation Verification Report confirming that the site is suitable for use has been submitted to, and agreed by, the Local Planning Authority.

(e) Any contamination, other than that reported by virtue of condition (a) and (b), encountered during the development of this site shall be brought to the attention of the Local Planning Authority as soon as practically possible; a scheme to render this contamination harmless shall be submitted to and agreed by, the Local Planning Authority and subsequently fully implemented prior to the occupation of this site.

Reason: To ensure that any contamination affecting the site is dealt with in a manner that safeguards human health, the built and natural environment and controlled waters.

4. Prior to occupation, each residential property shall incorporate an Electric Vehicle (EV) ready domestic charging point.

   Reason: To contribute to the objective of providing a sustainable transport network and to provide the necessary infrastructure to help off-set the adverse impact of the operational phase of the development on local air quality.

5. Prior to first occupation the development hereby permitted shall not be brought into use until the proposed access has been constructed, the existing access has been closed, and the verge has been reinstated to the current specification of Hertfordshire County Council and to the Local Planning Authority's satisfaction.

   Reason: In the interests of highway safety and amenity.

6. The proposed access hereby permitted shall not be brought into use until it has been hard-surfaced for the first 5.5 metres.

   Reason: To prevent loose material from passing onto the public highway which may be detrimental to highway safety.

7. Before the access is first brought into use, vehicle to vehicle visibility splays of 2.4 metres by 13 metres to the south direction and 2.4 metres by 20 metres to the north direction shall be provided and permanently maintained. Within which, there shall be no obstruction to visibility between 600 mm and 2.0 metres above the carriageway level. These measurements shall be taken from the intersection of the centre line of the permitted access with the edge of the carriageway of the highway respectively into the application site and from the intersection point along the edge of the carriageway.

   Reason: To provide adequate visibility for drivers entering and leaving the site.

8. The gradient of the access shall not be steeper than 1 in 20 for the first 6.0 metres from the edge of the carriageway.

   Reason: To ensure a vehicle is approximately level before being driven off and on to the highway.

9. The access shall be a minimum of 2.75 metres wide.

   Reason: To facilitate the free and safe flow of other traffic on the highway and the safety and convenience of pedestrians and people with a disability.

10. Any gates provided shall be set back a minimum of 5.5 metres from the edge of carriageway and shall open inwards to the site

    Reason: To allow a vehicle to wait clear of the carriageway or footway while the gates are being opened and closed.

11. The proposed development shall be carried out in accordance with the recommendations set out at paragraph 4.3 of the report prepared by Cherryfield Ecology, dated 01/09/2017, unless otherwise agreed in writing by the Local Planning Authority.

Reason: To ensure that the habitat and interests of protected species are safeguarded having regard to relevant planning legislation, as set out at paragraph 1 of the above report.

12. Details and/or samples of materials to be used on all external elevations and the roof of the development hereby permitted shall be submitted to and approved in writing by the Local Planning Authority before the development is commenced and the approved details shall be implemented on site.

Reason: To ensure that the development will have an acceptable appearance which does not detract from the appearance and character of the surrounding area.

13. The approved details of landscaping shown on approved drawing 5354/10D shall be carried out before the end of the first planting season following either the first occupation of any of the buildings or the completion of the development, whichever is the sooner. Any trees or plants which, within a period of 5 years from the completion of the development, die, are removed or become seriously damaged or diseased, shall be replaced during the next planting season with others of similar size and species, unless the Local Planning Authority agrees in writing to vary or dispense with this requirement.

Reason: To safeguard and enhance the appearance of the completed development and the visual amenity of the locality.

14. Notwithstanding the provisions of the Town and Country Planning (General Permitted Development) Order 2015 as amended no development as set out in Classes A, B, and C of Part 1 of Schedule 2 to the Order, (or any subsequent Statutory Instrument which revokes, amends and/or replaces those provisions) shall be carried out without first obtaining a specific planning permission from the Local Planning Authority.

Reason: Given the nature of this development, the Local Planning Authority considers that development which would normally be "permitted development" should be retained within planning control in the interests of the character and amenities of the area.

Proactive Statement:

Planning permission has been granted for this proposal. Discussion with the applicant to seek an acceptable solution was not necessary in this instance. The Council has therefore acted proactively in line with the requirements of the Framework (paragraphs 186 and 187) and in accordance with the Town and Country Planning (Development Management Procedure) (England) Order 2015.

Informative/s:

Informatives
1) EV Charging Point Specification:

Each charging point shall be installed by an appropriately certified electrician/electrical contractor in accordance with the following specification. The necessary certification of electrical installation should be submitted as evidence of appropriate installation to meet the requirements of Part P of the most current Building Regulations.
Cable and circuitry ratings should be of adequate size to ensure a minimum continuous current demand for the vehicle of 16A and a maximum demand of 32A (which is recommended for Eco developments)
o A separate dedicated circuit protected by an RBCO should be provided from the main distribution board, to a suitably enclosed termination point within a garage or an accessible enclosed termination point for future connection to an external charge point.
o The electrical circuit shall comply with the Electrical requirements of BS7671: 2008 as well as conform to the IET code of practice on Electric Vehicle Charging Equipment installation 2012 ISBN 978-1-84919-515-7 (PDF).
o If installed in a garage all conductive surfaces should be protected by supplementary protective equipotential bonding. For vehicle connecting points installed such that the vehicle can only be charged within the building, e.g. in a garage with a (non-extended) tethered lead, the PME earth may be used. For external installations the risk assessment outlined in the IET code of practice must be adopted, and may require additional earth stake or mat for the EV charging circuit. This should be installed as part of the EV ready installation to avoid significant on cost later.
o A list of authorised installers (for the Government's Electric Vehicle Homecharge Scheme) can be found at
https://www.gov.uk/government/organisations/office-for-low-emission-vehicles

2) Contaminated Land
The Environmental Protection Team has a web-page that aims to provide advice to potential developers, which includes a copy of a Planning Advice Note on "Development on Potentially Contaminated Land and/or for a Sensitive Land Use" in use across Hertfordshire and Bedfordshire. This can be found on www.north-herts.gov.uk by searching for contaminated land and I would be grateful if this fact could be passed on to the developers.

3) Highway Informative
Works to be undertaken on the adjoining highway shall be constructed to the satisfaction of the Highway Authority and in accordance with Hertfordshire County Council publication Roads in Hertfordshire Highway Design Guide. Before proceeding with the proposed development, the applicant shall contact hertsdirect@hertscc.gov.uk or for information use the HCC website www.hertsdirect.org. or call on 0300 1234 047 to obtain the requirements for a section 278 agreement for the associated road works and reinforcement works to the adjacent culvert and drainage ditch as part of the development. This should be carried out prior to any development work is carried out.

4) Demolition and construction phase
During the demolition and construction phase the guidance in BS5228-1:2009 (Code of Practice for noise Control on construction and open sites) should be adhered to. During the demolition and construction no activities should take place outside the following hours: Monday to Friday 08:00-18:00hrs; Saturdays 08:00-

13:00 hours and Sundays and Bank Holidays: no work at any time. Prior to the commencement of demolition of the existing buildings, a survey should be undertaken in order to identify the presence of asbestos containing materials. Any asbestos containing materials should be handled and disposed of appropriately. Where necessary this should include the use of licensed contractors and waste disposal sites licensed to receive asbestos.

5) European Protected Species licence
The applicant is reminded that a European Protected Species (EPS) licence is required prior to any works which may affect the protected species which it is recognised are present.

Signed:



Development & Conservation Manager
Date: 10 April 2018

Development Management
North Hertfordshire District Council
Council Offices
Gernon Road
Letchworth
Herts
SG6 3JF

NOTES

1 **Failure to satisfy conditions may invalidate this permission and/or result in enforcement action. Particular attention should be paid to the requirements of any condition in bold.**

2 Circular 04/2008 (Planning Related Fees) states that where an application is made under Article 21 of the Town and Country Planning (General Development Procedure) Order 1995, a fee will be payable for any consent, agreement or approval required by condition or limitation attached to the grant of planning permission.

3 The fee is £116 per request or £34 where the permission relates to an extension or alteration to a dwellinghouse or other development in the curtilage of the dwellinghouse. No fee is required for applications resulting from a condition removing "permitted development rights".

The request can be informal through the submission of a letter or plans, or formal through the completion of an application form and the submission of plans. Any number of conditions may be included on a single request. The form is available on the Council's website:
www.north-herts.gov.uk/home/planning/planning-applications/submit-planning-application

4 If the development hereby permitted is one that will require a new postal address/es then please contact the Council's **street naming and numbering service** on 01462 474431 or email SNN@north-herts.gov.uk who will advise you on how to apply for the new address/es.

Any proposed sales and/or marketing name to be adopted by the developer should be forwarded to the **street naming and numbering service,** prior to any publication of the site details and sales information.

5 If you are aggrieved by the decision of your local planning authority to refuse permission for the proposed development or to grant it subject to conditions, then you can appeal to the Secretary of State under section 78 of the Town and Country Planning Act 1990.

If you want to appeal against your local planning authority's decision then you must do so within 6 months of the date of this notice.

Appeals can be made online at: https://www.gov.uk/planning-inspectorate. If you are unable to access the online appeal form, please contact the Planning Inspectorate to obtain a paper copy of the appeal form on tel: 0303 444 5000.

The Secretary of State can allow a longer period for giving notice of an appeal, but he will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.

The Secretary of State need not consider an appeal if it seems to him that the local planning authority could not have granted planning permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements, to the provisions of any development order and to any directions given under a development order.

In practice, the Secretary of State does not refuse to consider appeals solely because the local planning authority based their decision on a direction given by him.

6 **Purchase Notices**

If either the local planning authority or the Secretary of State refuses permission to develop land or grants it subject to conditions, the owner may claim that he can neither put the land to a reasonably beneficial use in its existing state nor render the land capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted.

In these circumstances, the owner may serve a purchase notice on the Council

(District Council, London Borough Council or Common Council of the City of London) in whose area the land is situated. This notice will require the Council to purchase his interest in the land in accordance with the provisions of Part VI of the Town and Country Planning Act 1990.

7 The District Council and County Highway Authority wish to ensure that, in the implementation of the development, hereby approved, the highway verge adjacent to the property is not damaged or does not become unsightly due to the stationing of skips, parking of vehicles, storing of building materials etc thereon. Your attention is, therefore, drawn to the provisions of Section 131 of the Highways Act 1980 and to the Hertfordshire County Council Bylaws 1955 (specifically relating to grass margins and verges in Letchworth Garden City) by virtue of which such actions, unless authorised by the prior grant of a licence, constitute a prosecutable offence. Persons responsible for undertaking the development and any associated works are, therefore, strongly encouraged to take appropriate steps to ensure that no breach of the said legislation occurs during the course of such activities. In the event of any damage being caused it will be expected that suitable reinstatement is undertaken upon completion of the development. Failure to do so could also result in legal action being pursued. To obtain information regarding the issue of licences, contact Hertfordshire Highways, Hertfordshire County Council, County Hall, Pegs Lane, Hertford, SG138DQ or telephone 0300 1234 047.

THIS PLANNING PERMISSION DOES NOT CONSTITUTE APPROVAL UNDER BUILDING REGULATIONS AND IS NOT A LISTED BUILDING CONSENT OR CONSERVATION AREA CONSENT. IT DOES NOT CONVEY ANY APPROVAL OR CONSENT WHICH MAY BE REQUIRED UNDER ANY ENACTMENT, BYE-LAW, ORDER OR REGULATION OTHER THAN SECTION 57 OF THE TOWN AND COUNTRY PLANNING ACT 1990.

Consent for these works may be required from the Letchworth Garden City Heritage Foundation (www.letchworth.com/heritage-foundation) under the Scheme of Management or leasehold covenants. If you do not already have their approval, you are advised to contact the Heritage Foundation on home@letchworth.com or 01462 476017 to confirm whether you also need to submit an application to them.