

NORTH HERTS COUNCIL

MEMORANDUM

To: PLANNING CONTROL AND CONSERVATION Thomas Howe	From: ENVIRONMENTAL HEALTH Alan Stone Ext 4108
	Date: 1 st April 2026
Our Ref: 6628/26	Your : 26/00260/FP Ref:
Subject: Full Planning Permission: Erection of building for general industrial use including car parking, refuse, cycle storage and landscaping. Nup End Industrial Estate, Nup End, Old Knebworth, Knebworth, Hertfordshire, SG3 6QJ	

Comments:

Thank you for consulting Environmental Protection on this application. I can respond as follows.

Noise and other nuisances:

I have no concerns in relation to noise and other nuisances.

Land contamination:

According to our records has not been subject to any historical contaminative use and so do not require a land contamination assessment. I do, however, recommend that the following condition is placed on any decision notice, should you be minded to grant approval.

The applicant is advised that while the Council has no reason to believe this site is contaminated, and is not aware of any potentially contaminative past use, it is the developer's responsibility to ensure that final ground conditions are fit for the end use of the site. If during any site investigation, excavation, engineering or demolition/construction works evidence of land contamination is identified, the applicant shall notify the Local Planning Authority without delay. Any land contamination identified shall be remediated to the satisfaction of the Local Planning Authority to ensure that the site is made suitable for its end use.

Local Air Quality:

North Herts Council have specific air quality planning guidance that can be found at <http://www.north-herts.gov.uk/home/environmental-health/pollution/air-quality/air-quality-and-planning>

Application of the guidance to a development of this scale and location defines the site as being a MINOR scale development and so the following condition is recommended to ensure that appropriate local air quality mitigation is provided.

EV Recharging Infrastructure Condition

Prior to occupation, the development hereby permitted shall incorporate 2 Electric Vehicle (EV) ready domestic charging points.

Reason: To contribute to the objective of providing a sustainable transport network and to provide the necessary infrastructure to help off-set the adverse impact of the operational phase of the development on local air quality.

Informative

1) EV Charging Point Specification:

A charging point shall be installed by an appropriately certified electrician/electrical contractor in accordance with the following specification. The necessary certification of electrical installation should be submitted as evidence of appropriate installation to meet the requirements of Part P of the most current Building Regulations.

Cable and circuitry ratings should be of adequate size to ensure a minimum continuous current demand for the vehicle of 16A and a maximum demand of 32A (which is recommended for Eco developments)

- A separate dedicated circuit protected by an RBCO should be provided from the main distribution board, to a suitably enclosed termination point within a garage or an accessible enclosed termination point for future connection to an external charge point.
- The electrical circuit shall comply with the Electrical requirements of BS7671: 2008 as well as conform to the IET code of practice on Electric Vehicle Charging Equipment installation 2012 ISBN 978-1-84919-515-7 (PDF). This includes requirements such as ensuring the Charging Equipment integral protective device shall be at least Type A RCD (required to comply with BS EN 61851 Mode 3 charging).
- If installed in a garage all conductive surfaces should be protected by supplementary protective equipotential bonding. For vehicle connecting points installed such that the vehicle can only be charged within the building, e.g. in a garage with a (non-extended) tethered lead, the PME earth may be used. For external installations the risk assessment outlined in the IET code of practice must be adopted, and may require additional earth stake or mat for the EV charging circuit. This should be installed as part of the EV ready installation to avoid significant on cost later.
- A list of authorised installers (for the Government's Electric Vehicle Homecharge Scheme) can be found at <https://www.gov.uk/government/organisations/office-for-low-emission-vehicles>
- UK Government issued legislation in 2021 to require domestic EV charge points to be smart, thus we recommend that all charge points will be capable of smart charging, as detailed in UK Gov regulations.

2) The above condition is considered relevant and reasonable for the following reasons:

- Paragraphs 170 (e), 181 of the NPPF, which refer to the effects (including cumulative effects) of pollution (including air pollution) on health, the natural environment (including air quality).
- Paragraphs 102 (d), 105 (e) and 110 (e) of the NPPF, which refer to the need to promote sustainable transport including the provision for charging plug-in and other ultra low emission vehicles.
- HCC Local Transport Plan (LTP4) 2018-2031 which includes an objective to 'preserve the character and quality of the Hertfordshire environment' and 'make journeys and their impact safer and healthier', as well as its Emissions Reduction Policy 19.
- It is consistent with the approach specified in the NHDC Air Quality Planning Guidance Document, which is referenced within the current consultation version of the Local Plan.

If you have any queries, then please do not hesitate to contact me.

Regards
Alan Stone