

NORTH HERTS COUNCIL

MEMORANDUM

To: PLANNING CONTROL AND CONSERVATION Melissa Tyler	From: ENVIRONMENTAL HEALTH Gareth Jones Gareth.jones@north.herts.gov.uk
	Date: 23 rd September 2024
Our Ref:	Your : 23/00407/FP Ref:
Subject: Conversion of Node Court to 8no. dwellings. Conversion of Midden building to residential and the erection of 6no. terraced dwelling-houses as development to facilitate the restoration of Node Court together with associated car parking, landscaping, boundary treatment and ancillary works	

Comments:

Thank you for consulting Environmental Protection on this application.

I have no objection to the proposals however, I would comment as follows:

Noise

Prior to the commencement of the development, a detailed construction management plan shall be submitted to and approved in writing by the Local Planning Authority, and the plan shall include the following:

- a) The conversion/construction programme and phasing
- b) Hours of operation, delivery and storage of materials
- c) Control of dust and dirt arising from conversion/construction
- d) Waste management proposals
- e) Mechanisms to deal with environmental impacts such as noise, air quality, light and odour during construction.

Reason: In the interests of environmental impacts

Local Air Quality:

North Herts Council have specific air quality planning guidance that can be found at <http://www.north-herts.gov.uk/home/environmental-health/pollution/air-quality/air-quality-and-planning>

Application of the guidance to a development of this scale and location defines the site as being a MINOR scale development and so the following condition is recommended to ensure that appropriate local air quality mitigation is provided.

EV Recharging Infrastructure Condition

Prior to occupation, the new dwellings shall incorporate an Electric Vehicle (EV) ready domestic charging point.

Reason: To contribute to the objective of providing a sustainable transport network and to provide the necessary infrastructure to help off-set the adverse impact of the operational phase of the development on local air quality.

Informative

1) EV Charging Point Specification:

A charging point shall be installed by an appropriately certified electrician/electrical contractor in accordance with the following specification. The necessary certification of electrical installation should be submitted as evidence of appropriate installation to meet the requirements of Part P of the most current Building Regulations.

Cable and circuitry ratings should be of adequate size to ensure a minimum continuous current demand for the vehicle of 16A and a maximum demand of 32A (which is recommended for Eco developments)

- A separate dedicated circuit protected by an RBCO should be provided from the main distribution board, to a suitably enclosed termination point within a garage or an accessible enclosed termination point for future connection to an external charge point.
- The electrical circuit shall comply with the Electrical requirements of BS7671: 2008 as well as conform to the IET code of practice on Electric Vehicle Charging Equipment installation 2012 ISBN 978-1-84919-515-7 (PDF). This includes requirements such as ensuring the Charging Equipment integral protective device shall be at least Type A RCD (required to comply with BS EN 61851 Mode 3 charging).
- If installed in a garage all conductive surfaces should be protected by supplementary protective equipotential bonding. For vehicle connecting points installed such that the vehicle can only be charged within the building, e.g. in a garage with a (non-extended) tethered lead, the PME earth may be used. For external installations the risk assessment outlined in the IET code of practice must be adopted, and may require additional earth stake or mat for the EV charging circuit. This should be installed as part of the EV ready installation to avoid significant on cost later.
- A list of authorised installers (for the Government's Electric Vehicle Homecharge Scheme) can be found at <https://www.gov.uk/government/organisations/office-for-low-emission-vehicles>
- UK Government issued legislation in 2021 to require domestic EV charge points to be smart, thus we recommend that all charge points will be capable of smart charging, as detailed in UK Gov regulations.

2) The above condition is considered relevant and reasonable for the following reasons:

- Paragraphs 170 (e), 181 of the NPPF, which refer to the effects (including cumulative effects) of pollution (including air pollution) on health, the natural environment (including air quality).
- Paragraphs 102 (d), 105 (e) and 110 (e) of the NPPF, which refer to the need to promote sustainable transport including the provision for charging plug-in and other ultra low emission vehicles.
- HCC Local Transport Plan (LTP4) 2018-2031 which includes an objective to 'preserve the character and quality of the Hertfordshire environment' and 'make journeys and their impact safer and healthier', as well as its Emissions Reduction Policy 19.
- It is consistent with the approach specified in the NHDC Air Quality Planning Guidance Document, which is referenced within the current consultation version of the Local Plan.

Contaminated Land:

The applicant is advised that while the Council has no reason to believe this site is contaminated, and is not aware of any potentially contaminative past use, it is the developer's responsibility to ensure that final ground conditions are fit for the end use of the site. If during any site investigation, excavation, engineering or construction works evidence of land contamination is identified, the applicant shall notify the Local Planning Authority without delay. Any land contamination identified shall be remediated to the satisfaction of the Local Planning Authority to ensure that the site is made suitable for its end use.

Regards
Gareth Jones