NORTH HERTFORDSHIRE DISTRICT COUNCIL
Correspondence address:
North Hertfordshire District Council, PO BOX 480, Sale, M33 0DE
Telephone: (01462) 474000
Text Phone: (01462) 474800.
DX 745063, Sale 8

Date: 18 April 2018

Our Ref: 18/00810/DOC

Mr Ian Turvey
TDC New Homes
92 Green Drift
Royston
SG8 5BT

Contact: Melissa Tyler
Direct Line: 01462 474245
Email: melissa.tyler@north-herts.gov.uk

Dear Sir/Madam

Discharge of Conditions : Discharge of Condition 7 (Waste Management) as attached to Planning Application 17/02482/1 granted on 24/02/2018.
2 Garden Lane, Royston, Hertfordshire, SG8 9EH,

Please quote the following reference: 18/00810/DOC on all correspondence.

I refer to your application received on 16 March 2018 which seeks approval for details involving the waste management on the above development pursuant to Condition 7 of the planning permission reference number 17/02482/1.

Following consultation with the North Herts Waste Department the following comments were received:

Doors to bin stores should be sufficient in widths to allow the movement of bins at their widest and prevent entrapment of limbs. This is likely to be a minimum of 20cm in addition to the widest bin contained in the bin store.

Walls and doors should have protection strips to prevent damage and a mechanism for holding doors open should be available.

Doors should ideally be keypad entry or standard fire brigade keys. We do not support the use of electronic key fobs.

Roller shutters on bin stores can be considered to save space however the additional noise impacts should be considered.

Dropped kerbs should be provided to allow for ease of movement of bins to the collection vehicle and the pathway should be 1.5m in width taking the most direct route avoiding passing parked cars.

We do not advise the use of bin compactors, as they often cause excessive damage to bins or cause waste to get stuck inside bins. If bin compactors are used on site you should advise your waste collection contractor.

Bins in communal bin stores should be manoeuvrable to the refuse collection vehicle without the need to move other bins.

Separate internal storage provision for waste should be provided in kitchen areas to support the recycling of different waste streams to support the National Planning Policy for Waste's requirements to support driving waste up the waste hierarchy. We see this has been taken care of.

The surface to the collection point should be uninterrupted, level with no gravel or similar covering, and have a width to enable the easy passage of wheeled bins. For two-wheeled bins this should be 1 metre for four-wheeled bins this should be 1.5 metres wide (including doorways), with a maximum gradient of 1:12.

For flats, bins should be ordered direct from the Council's contractor 10 weeks in advance of first occupation to ensure they arrive in time for the first residents moving in.

Pull distances to the collection vehicle should not exceed 15m in accordance with BS5906:2005. This has also been noted.

Further advice on waste provision for developments is available on our website.
http://www.north-herts.gov.uk/home/planning/waste-and-recycling-provision

The submitted information is considered to be acceptable by the Local Planning Authority and sufficient to enable the condition to be discharged.

I would remind you that the requirements of the afore-mentioned Condition will not be fully complied with until the development has been completed in accordance with the details hereby approved. Should you require the Local Planning Authority's agreement in this respect then you will need to apply in writing following the completion of the development.

Yours faithfully



Simon Ellis
Development & Conservation Manager