

COOLING:
THE COOLING REQUIREMENT FOR THIS
SITE IS 3.23kW. THEREFORE THE EXISTING
COOLING REQUIREMENTS IS SUFFICIENT

PROPOSED BTEE 3No. MK2 BOB I.D.No. EQU200000000595946,
EQU200000000595947 & EQU200000000595948 TO BE INSTALLED ON
EXISTING CABLE LADDER WITHIN BTEE CABIN 1 (1No. PER SECTOR)

BTEE 1No. MK1 BOB I.D. No. EQU900387936 TO BE REMOVED

EXISTING 300mm WIDE VERTICAL CABLE LADDER TO BE RELOCATED

BTEE 1No. BTS3900L CABINET TO BE REMOVED

H3G & BTEE 1No. FLEXI CABINET TO BE REMOVED

H3G 3No. RD0313 MK2 UCU INSTALLED
WITHIN FLEXI CABINET TO BE REMOVED

PROPOSED BTEE 1No. AIRI CABINET I.D. No. EQU100000000418451
c/w 7No. 2kW RECTIFIERS TO BE INSTALLED WITHIN BTEE CABIN 1

H3G & BTEE 1No. TRANSMISSION RACK

PROPOSED BTEE 1No. AYGE GPS NODE AT 3.0m
MEAN HEIGHT, I.D.No. EQU200000000595949 TO BE
INSTALLED ON EXISTING CABIN WALL

H3G & BTEE 1No. 20-WAY ROXTEC
GLANDS WITH 11No. SPAREWAYS
H3G & BTEE 1No. 20-WAY ROXTEC
GLANDS WITH 6No. SPAREWAYS


H3G & BTEE 1No. CRABTREE AC DISTRIBUTION
BOARD TO BE REMOVED

PROPOSED BTEE 1No. SCHNEIDER ACTI9 ISOBAR AC
DISTRIBUTION TO BE INSTALLED WITHIN BTEE CABIN 1

H3G & BTEE 1No. ALIFABS MONITOR 3
FAN TRAY (12kw SYSTEM)



H3G & BTEE 1No. WALL MOUNTED
ELTEK PSU c/w 4No. 3kW RECTIFIERS



CABIN 1 BTEE
EQUIPMENT PLAN

©2020 Cellnex
All rights reserved. No part of this publication may be reproduced, stored in
a retrieval system or transmitted in any form or by any means (Electronic,
Mechanical, Photocopying, Recording or otherwise), without the prior
written consent of the Company.

NOTES

PROJ No . COL.MOD.UK.0003691

CELL No. 91657

BT SKYLINE No.
SG0037

30	COL.MOD.UK.0003691 PLANNING ISSUE	14/08/25	HFC	HFC
29	COL.MOD.UK.0001495 PLANNING AMEND	04/02/25	GBC	GBC
28	COL.MOD.UK.0001495 PLANNING AMEND	27/11/24	GBC	GBC
27	COL.MOD.UK.0001495 PLANNING AMEND	28/10/24	GBC	GBC
26	COL.MOD.UK.0001495 PLANNING	08/12/23	GBC	GBC
ISS	REVISION	DATE	DRN	APP



CELLNEX UK
R+, 4TH FLOOR, 2 BLA GRAVE STREET, READING, RG1 1AZ
Tel. 020 4526 8553

SITE No UK-HT-001289
LETCWORTH ATE_SUB TEC
NEVELLS ROAD
LETCWORTH
HERTFORDSHIRE
SG6 4TS

NGR TL 21600 32800

OS GRID

TITLE
CABIN 1 BTEE EQUIPMENT PLAN
PROPOSED
BTEE LTD

SCALE 1:50

DRAWN IM 01/06/11

APPROVED HFC 14/08/25

DRG No. Sheet 1 of 1 Rev

UKHT001289- 02-111-MD030 30

FEINT DETAILS INDICATE LOCATIONS
RESERVED FOR OTHER PROPOSALS
WHICH MAY BE THE SUBJECT OF
SEPARATE APPLICATIONS