



www.north-herts.gov.uk

NORTH HERTFORDSHIRE DISTRICT COUNCIL

Town and Country Planning Act 1990

Correspondence Address:

Sworders
The Gatehouse
Hadham Hall
Little Hadham
Ware
SG11 2EB

Developer

Mr And Mrs Jani

PARTICULARS OF DEVELOPMENT

Application:	24/01733/PNQ
Proposal:	Conversion of former Poultry building into 3 residential dwellings with all associated building works.
Location:	Woodcotes, Fears Green, Sandon, Buntingford, Hertfordshire, SG9 0QZ
Plan Nos:	220230-PL-001, 220230-PL-002, 220230-PL-010 220230-PL-030, 220230-PL-100, 220230-PL-300

North Herts Council, as local planning authority, hereby confirm that conditional **prior approval is given** under Class Q, part 3 of Schedule 2 of the Town and Country Planning (General Permitted Development) Order 2015 for the proposed development at the address shown above, as described by the description shown above.

The development must be carried out wholly in accordance with the information and details that the developer provided to the local planning authority on 05.08.2024 and in compliance with the conditions listed below.

1. The development hereby permitted shall be begun before the expiration of 3 years from the date of this permission.

Reason: To comply with the provisions of Section 91 of the Town and Country Planning Act 1990 as amended by Section 51 of the Planning and Compulsory Purchase Act 2004.

2.
 - (a) No development approved by this permission shall be commenced prior to the submission to, and agreement of the Local Planning Authority of written information allowing a preliminary environmental risk assessment to be undertaken, which allows the creation of a Conceptual Site Model which indicates sources, pathways and receptors. It should identify the current and past land uses of this site (and adjacent sites), with a view to determining the presence of contamination likely to be harmful to human health, and the built and natural environment.
 - (b) If the Local Planning Authority is of the opinion that the report which discharges condition (a), above, indicates a reasonable likelihood of harmful contamination then no development approved by this permission shall be commenced until a Site Investigation (Phase II environmental risk assessment) report has been submitted to and approved by the Local Planning Authority which includes:
 - (i) A full identification of the location and concentration of all pollutants on this site and the presence of relevant receptors, and;
 - (ii) The results from the application of an appropriate risk assessment methodology
 - (c) No development approved by this permission (other than that necessary for the discharge of this condition) shall be commenced until a Remediation Method Statement report; if required as a result of (b), above; has been submitted to and approved by the Local Planning Authority.
 - (d) This site shall not be occupied, or brought into use, until:
 - (i) All works which form part of the Remediation Method Statement report pursuant to the discharge of condition (c) above have been fully completed and if required a formal agreement is submitted that commits to ongoing monitoring and/or maintenance of the remediation scheme.
 - (ii) A Remediation Verification Report confirming that the site is suitable for use has been submitted to, and agreed by, the Local Planning Authority.
 - (e) Any contamination, other than that reported by virtue of condition (a) and (b), encountered during the development of this site shall be brought to the attention of the Local Planning Authority as soon as practically possible; a scheme to render this contamination harmless shall be submitted to, and agreed by, the Local Planning Authority and subsequently fully implemented prior to the occupation of this site.

Reason: To ensure that any contamination affecting the site is dealt with in a manner that safeguards human health, the built and natural environment and controlled waters.

3. Prior to occupation, each of the new dwellings shall incorporate an Electric Vehicle (EV) ready domestic charging point.

Reason: To contribute to the objective of providing a sustainable transport network and to provide the necessary infrastructure to help off-set the adverse impact of the operational phase of the development on local air quality.

4. Details and/or samples of materials to be used on all external elevations and the roof of the converted building hereby permitted shall be submitted to and approved in writing by the Local Planning Authority before the development is commenced and the approved details shall be implemented on site.

Reason: To ensure that the development will have an acceptable appearance which does not detract from the appearance and character of the surrounding area.

Informative/s:

1. 1) EV Charging Point Specification:

A charging point shall be installed by an appropriately certified electrician/electrical contractor in accordance with the following specification. The necessary certification of electrical installation should be submitted as evidence of appropriate installation to meet the requirements of Part P of the most current Building Regulations.

Cable and circuitry ratings should be of adequate size to ensure a minimum continuous current demand for the vehicle of 16A and a maximum demand of 32A (which is recommended for Eco developments)

- o A separate dedicated circuit protected by an RBCO should be provided from the main distribution board, to a suitably enclosed termination point within a garage or an accessible enclosed termination point for future connection to an external charge point.

- o The electrical circuit shall comply with the Electrical requirements of BS7671: 2008 as well as conform to the IET code of practice on Electric Vehicle Charging Equipment installation 2012 ISBN 978-1-84919-515-7 (PDF). This includes requirements such as ensuring the Charging Equipment integral protective device shall be at least Type A RCD (required to comply with BS EN 61851 Mode 3 charging).

- o If installed in a garage all conductive surfaces should be protected by supplementary protective equipotential bonding. For vehicle connecting points installed such that the vehicle can only be charged within the building, e.g. in a

garage with a (non-extended) tethered lead, the PME earth may be used. For external installations the risk assessment outlined in the IET code of practice must be adopted, and may require additional earth stake or mat for the EV charging circuit. This should be installed as part of the EV ready installation to avoid significant on cost later.

- o A list of authorised installers (for the Government's Electric Vehicle Homecharge Scheme) can be found at <https://www.gov.uk/government/organisations/office-for-low-emission-vehicles>
- o UK Government issued legislation in 2021 to require domestic EV charge points to be smart, thus we recommend that all charge points will be capable of smart charging, as detailed in UK Gov regulations.

2) The above condition is considered relevant and reasonable for the following reasons:

- o Paragraphs 170 (e), 181 of the NPPF, which refer to the effects (including cumulative effects) of pollution (including air pollution) on health, the natural environment (including air quality).
- o Paragraphs 102 (d), 105 (e) and 110 (e) of the NPPF, which refer to the need to promote sustainable transport including the provision for charging plug-in and other ultra low emission vehicles.
- o HCC Local Transport Plan (LTP4) 2018-2031 which includes an objective to 'preserve the character and quality of the Hertfordshire environment' and 'make journeys and their impact safer and healthier', as well as its Emissions Reduction Policy 19.
- o It is consistent with the approach specified in the NHDC Air Quality Planning Guidance Document, which is referenced within the current consultation version of the Local Plan.

2. Doors to bin stores should be sufficient in width to allow the movement of bins at their widest and prevent entrapment of limbs. This is likely to be a minimum of 20cm in addition to the widest bin contained in the bin store.
Walls and doors should have protection strips to prevent damage and a mechanism for holding doors open should be available.
Doors should ideally be keypad entry or standard fire brigade keys. We do not support the use of electronic key fobs.
Roller shutters on bin stores can be considered to save space however the additional noise impacts should be considered.
Dropped kerbs should be provided to allow for ease of movement of bins to the collection vehicle and the pathway should be 1.5m in width taking the most direct route avoiding passing parked cars.
We do not advise the use of bin compactors, as they often cause excessive damage to bins or cause waste to get stuck inside bins. If bin compactors are used on site you should advise your waste collection contractor.

Bins in communal bin stores should be manoeuvrable to the refuse collection vehicle without the need to move other bins.

For flats, bins should be ordered direct from the Council's contractor 10 weeks in advance of first occupation to ensure they arrive in time for the first residents moving in.

Pull distances to the collection vehicle should not exceed 15m in accordance with BS5906:2005.

Separate internal storage provision for waste should be provided in kitchen areas to support the recycling of different waste streams to support the National Planning Policy for Waste's requirements to support driving waste up the waste hierarchy.

Storage areas should be conveniently located with easy access for residents - residents should not have to take their waste and recycling more than 30metres to a bin storage area, or take their waste receptacles more than 25metres to a collection point, (usually kerbside) in accordance with Building Regulations Approved Document H Guidance.

Consideration should be given to parking arrangements alongside or opposite the access to individual streets. If car parking is likely in the vicinity of junctions then parking restrictions may be required to ensure access is not inhibited.

For infill applications consideration should be given to parking arrangements alongside or opposite the access to the site. If car parking is currently permitted the consideration of parking restrictions may be required to ensure access is not inhibited.

For houses, bins should be ordered direct from the Council's contractor 2 weeks in advance of first occupation to ensure they arrive in time for the first residents moving in.

Pull distances from the storage point to the collection point should not be within close proximity to parked cars.

The gravel drive makes pulling bins difficult and consideration should be given to whether this surface is the most suitable or whether bins stored closer to the collection point would be more preferable.

The applicant should note that collections occur from the kerbside and residents will be required to present their bins in this location on collection day.

Further general advice on waste provision for developments is available on our website: <http://www.north-herts.gov.uk/home/planning/waste-and-recycling-provision> The bin requirements stated there are specific to North Herts, but the rest of the advice is general.

3. In regards to the submitted Preliminary Ecological Appraisal (PEA) it is evident the poultry building (B1) was identified as being occupied by two barn owls. Nesting adults and dependent young are legally protected against disturbance and the PEA makes recommendations to ensure works to the barn can proceed lawfully. The applicant is advised to follow the recommendations as set out in the report.

4. The applicant is advised during the proposed works to the buildings, should bats or evidence of roosting bats be found, works to the buildings should cease immediately and Natural England be contacted for advice.

Signed:



Shaun Greaves
Development and Conservation Manager

Development Management
North Herts Council
Council Offices
Gernon Road
Letchworth
Herts
SG6 3JF

Date: 25 September 2024

The Council's Privacy Notice is available on our website: <https://www.north-herts.gov.uk/home/council-data-and-performance/data-protection/information-management-gdpr>

NOTES

- 1 **Failure to satisfy conditions may invalidate this permission and/or result in enforcement action. Particular attention should be paid to the requirements of any condition in bold.**
- 2 Circular 04/2008 (Planning Related Fees) states that where an application is made under Article 21 of the Town and Country Planning (General Development Procedure) Order 1995, a fee will be payable for any consent, agreement or approval required by condition or limitation attached to the grant of planning permission.
- 3 The fee is £145 per request or £43 where the permission relates to an extension or alteration to a dwellinghouse or other development in the curtilage of the dwellinghouse.

The request can be informal through the submission of a letter or plans, or formal through the completion of an application form and the submission of plans. Any number of conditions may be included on a single request. The form is available on the Council's website:
www.north-herts.gov.uk/home/planning/planning-applications/submit-planning-application
- 4 If you are aggrieved by the decision of your local planning authority to refuse permission for the proposed development or to grant it subject to conditions, then you can appeal to the Secretary of State under section 78 of the Town and Country Planning Act 1990.

Appeals must be made using a form which you can get from the Planning Inspectorate at Suite C, 4th Floor, Spectrum Building, Bond Street, Bristol, BS1 3LG or online at www.planningportal.gov.uk/planning/appeals.

The Secretary of State can allow a longer period for giving notice of an appeal, but he will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.

The Secretary of State need not consider an appeal if it seems to him that the local planning authority could not have granted planning permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements, to the provisions of any development order and to any directions given under a development order.

In practice, the Secretary of State does not refuse to consider appeals solely because the local planning authority based their decision on a direction given by him.

5 Purchase Notices

If either the local planning authority or the Secretary of State refuses permission to develop land or grants it subject to conditions, the owner may claim that he can neither put the land to a reasonably beneficial use in its existing state nor render the land capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted.

In these circumstances, the owner may serve a purchase notice on the Council (District Council, London Borough Council or Common Council of the City of London) in whose area the land is situated. This notice will require the Council to purchase his interest in the land in accordance with the provisions of Part VI of the Town and Country Planning Act 1990.

- 6 The District Council and County Highway Authority wish to ensure that, in the implementation of the development, hereby approved, the highway verge adjacent to the property is not damaged or does not become unsightly due to the stationing of skips, parking of vehicles, storing of building materials etc thereon. Your attention is, therefore, drawn to the provisions of Section 131 of the Highways Act 1980 and to the Hertfordshire County Council Bylaws 1955 (specifically relating to grass margins and verges in Letchworth Garden City) by virtue of which such actions, unless authorised by the prior grant of a licence, constitute a prosecutable offence. Persons responsible for undertaking the development and any associated works are, therefore, strongly encouraged to take appropriate steps to ensure that no breach of the said legislation occurs during the course of such activities. In the event of any damage being caused it will be expected that suitable reinstatement is undertaken upon completion of the development. Failure to do so could also result in legal action being pursued. To obtain information regarding the issue of licences, contact Hertfordshire Highways, Hertfordshire County Council, County Hall, Pegs Lane, Hertford, SG138DQ or telephone 0300 1234 047.

THIS PLANNING PERMISSION DOES NOT CONSTITUTE APPROVAL UNDER BUILDING REGULATIONS AND IS NOT A LISTED BUILDING CONSENT OR CONSERVATION AREA CONSENT. IT DOES NOT CONVEY ANY APPROVAL OR CONSENT WHICH MAY BE REQUIRED UNDER ANY ENACTMENT, BYE-LAW, ORDER OR REGULATION OTHER THAN SECTION 57 OF THE TOWN AND COUNTRY PLANNING ACT 1990.