



Planning Applications – Suggested Informative Statements and Conditions Report

If you would like to discuss any of the points in this document please contact us on 0345 0263912 or email planningliaison@anglianwater.co.uk.

AW Site Reference: 226324/1/0232552

Local Planning Authority: North Hertfordshire District

Site: Starwood House Avenue One Letchworth
Garden City Hertfordshire SG6 2HB

Proposal: Erection of two buildings including three units for Flexible Use Classes including Eg (ii) (iii), B2, B8, including servicing, parking, access, landscaping .

Planning application: 25/01196/FP

Prepared by: Pre-Development Team

Date: 29 September 2025

ASSETS

Section 1 - Assets Affected

There are assets owned by Anglian Water or those subject to an adoption agreement within or close to the development boundary that may affect the layout of the site. Anglian Water would ask that the following text be included within your Notice should permission be granted.

Anglian Water has assets close to or crossing this site or there are assets subject to an adoption agreement. Therefore the site layout should take this into account and accommodate those assets within either prospectively adoptable highways or public open space. If this is not practicable then the sewers will need to be diverted at the developers cost under Section 185 of the Water Industry Act 1991. or, in the case of apparatus under an adoption agreement, liaise with the owners of the apparatus. It should be noted that the diversion works should normally be completed before development can commence.

WASTEWATER SERVICES

Section 2 - Wastewater Treatment

When assessing the receiving water recycling centre's (WRC) dry weather flow (DWF) headroom we take the latest Q90 DWF figures, as verified by the Environment Agency, and add to this sites with planning consent.

Based on the above assessment, Letchworth WRC is within the acceptance parameters and can accommodate the flows from the proposed growth. .

Letchworth Water Recycling Centre is included in our nutrient removal programme and will be designed to technically achievable limits (TAL). For the majority of WRCs in this programme this will be for phosphorous removal where TAL is 0.25mg/l. When both TAL and DWF capacity constraints are forecast at a WRC, either due to housing/non-domestic growth or infiltration into the network then alternative options will need to be considered.

Some WRCs will be either too remote or not near another WRC with capacity. The impact of environmental pressures, including sites at technical achievable limits, and the approach required to enable future sustainable growth is something we will continue to discuss with the Environment Agency and key stakeholders, including local planning authorities.

Where TAL impacts on the DWF headroom and our ability to accommodate future growth we may start objecting, if we are not doing so already, to planning applications in the impacted catchments.

Section 3 - Used Water Network

This response has been based on the following submitted documents:

Flood Risk Assessment and Drainage Strategy Report 40365-BGL-XX-XX-RP-D-0001 Version V2 Date 25.04.2025

The sewerage system at present has available capacity for these flows. If the developer wishes to connect to our sewerage network they should serve notice under Section 106 of the Water Industry Act 1991. We will then advise them of the most suitable point of connection.

1. INFORMATIVE - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087 Option 2.

2. INFORMATIVE - Protection of existing assets - A public sewer is shown on record plans within the land identified for the proposed development. It appears that development proposals will affect existing public sewers. It is recommended that the applicant contacts Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers will not be permitted (without agreement) from Anglian Water.

3. INFORMATIVE - Building near to a public sewer - No building will be permitted within the statutory easement width of 3 metres from the pipeline without agreement from Anglian Water. Please contact Development Services Team on 0345 606 6087 Option 2.

4. INFORMATIVE: The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 Option 2 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements.

Section 4 - Surface Water Disposal

Anglian Water has reviewed the submitted documents (Flood Risk Assessment & Drainage Strategy Report Ref: 40365-BGL-XX-XX-RP-D-0001 Version V2 Date 25.04.2025/TECHNICAL NOTE Response to LLFA Comments Dated 01 August 2025 40365-BGL-XX-XX-TN-C-0002) and can confirm that these are acceptable to us with a maximum discharge of 6.2l/s.

We require these documents to be listed as approved plans/documents if permission is granted.

